

## 1 Scope

This appendix to ENA ER G81 Part 1 covers the design and planning of new low voltage services and mains and associated high voltage to low voltage substations for the purpose of connecting housing developments to the electricity distribution network of Electricity North West Limited (Electricity North West). (This Part 1 of ES281 provides the information, specific to Electricity North West, required by Appendix B of Part 1 of ENA ER G81.)

## 2 Design and Planning of New LV Networks for the Connection of Housing Developments

### 2.1 General

The design of all new works to be adopted by Electricity North West shall comply with EPD279 and the associated policy for each voltage level, specifically:

- EPD282 for new HV networks, and;
- EPD283 for new LV networks.

All these EPDs shall be read in conjunction with each other and designers should be aware of the details, some of which are described in this document.

### 2.2 Connections Design

The design of third party connections for new housing developments is also governed by ES210 and the following associated specifications.

- ES211 for the provision of connections for street electrical fixtures.
- ES212 for the provision of service connections of up to 60kVA rating.
- ES213 for the provision of multiple housing connections.
- ES214 for the provision of LV connections up to 300kVA.
- ES215 for the provision of connections up to 1500kVA.
- ES216 for the provision of 11kV Connections up to 15MVA.

The above specifications provide design guidance for new connections, which compliments this document.

### 2.3 Security of Supply

All networks and parts of networks, to be adopted by Electricity North West, shall comply with ENA ER P2/7. This requirement is imposed by a condition of Electricity North West's Distribution Licence. In particular, in the context of housing developments, any load group in excess of 1MW shall have a switched alternative means of connection, available for a first circuit outage.

## 2.4 HV Network

The design fault level for HV networks shall be 250MVA. This is equivalent to 13.1kA at 11kV or 21.9kA at 6.6kV.

The two sizes of HV aluminium core triplex cable, permitted by the materials specification ES281 Part 2, are described in [Table 1](#).

**Table 1 – 11kV Single Core, Solid Aluminium Conductor, Polymeric Insulation, Copper Screen and laid in Triplex Formation**

11kV ALUMINIUM TRIPLEX CABLE CROSS-SECTION (MM <sup>2</sup> )	MAXIMUM CONTINUOUS RATING (A)		
	Laid Direct, Ungrouped Cable $g = 1.2\text{KmW}^{-1}$ $T_g = 15^\circ\text{C}$	In Ducts, One Cable Per Duct, Ungrouped Cable, $g = 1.2\text{KmW}^{-1}$ $T_g = 15^\circ\text{C}$	In Air & Shade, Ambient Temperature 25°C
95	245	214	285
300	461	403	580

Aluminium cored cable, having a cross-section of 95mm<sup>2</sup>, may be used for any of the following:

- a new connection to or from an overhead line, or where an overhead line forms part of the circuit, between points of isolation, provided that the current rating of the cable does not limit the rating of the circuit; or
- a new connection between a transformer and its local switchgear.

However, all other new cables shall have a cross-section of 300mm<sup>2</sup> aluminium.

Most HV circuits within Electricity North West's network operate radially with one or more open points, which provide alternative means of connection. New substations may be tee-connected to underground circuits, provided that:

- no such tee is connected between a primary substation and the first downstream switching point;
- the underground circuit has a maximum of four interconnected ends;
- the point of connection for a new substation to the existing Network, measured along the proposed cable route, exceeds 250m; and
- the number of customers, at repair-time risk, is not expected to exceed 200 (transformers connected between points of isolation shall be limited to a maximum of five transformers).

## 2.5 Distribution Substations

Distribution Substations shall be designed in accordance with ES352.

Distribution Substations shall normally be housed in a GRP enclosure, meeting the requirements of ES301. Alternatively, enclosed brick-built substations are acceptable.

Distribution Substations shall be sited in accordance with ES352 and CP226 and shall normally be located near the centre of the load group they are intended to connect. Electricity North West may require an alternative location for a substation, in order to enable its use for other purposes. Designers are, therefore, advised to consult the Engineer at an early stage, when locating substations. Any additional cabling costs incurred by such a change in location will be borne by Electricity North West.

A number of different phasing connections are employed within Electricity North West's networks. Transformer windings and HV and LV busbars shall be connected in accordance with local conventions and requirements. Where a new substation is to feed LV network, phasing shall match that of the surrounding network, even if no interconnection facility is to be installed initially.

Most new housing developments will each be catered for by the provision of one or two new Distribution Substations. Normally the maximum transformer rating to be used in determining the optimum number of substations for a development is 800kVA.

Distribution transformers shall comply with ES322.

The ratings of transformers, to be adopted by Electricity North West, shall be selected from the standard ratings allowed by the latest issue of ENA TS 35-1 Part 1, and shall be such that the initial utilisation factors are not less than 0.6. The transformer shall be sized to match the calculated demand, or to achieve other requirements such as voltage regulation. The maximum transformer size to be adopted shall not exceed 1000kVA.

Any new Distribution Substation shall have facilities for the connection of a mobile generator to the LV distribution board.

Remote Control (RC) functionality, e.g. actuators for feeder switches, shall be considered for new Distribution Stations, in accordance with EPD282.

## 2.6 Prospective Short-Circuit Current

For a network fed by a single 1000kVA transformer the maximum PSCC, at the customer's terminals, is not expected to exceed the following values:

Three phase = 27kA;

Single phase = 16kA.

Fault contribution from distributed generation on the LV Network should be taken into account.

Further guidance on the determination of PSCC can be obtained from ENA ER P25 for single phase and ENA ER P26 for three phase.

## 2.7 Protection of LV Networks

LV networks and transformers shall be protected in accordance with CP331. In particular, the following points shall be satisfied.

- Designs shall ensure that all LV mains are protected by fuses such that a single-phase to earth or neutral fault will be disconnected in 100s in an underground cable or 10s on an overhead line.
- Designs for new distributors shall not include any additional fuses downstream of the substation, e.g. in a link-box.

In principle, LV fuse-links shall be selected so as to comply with each of the following.

- Distributors shall be protected such that faults will be cleared within the stated times;
- Discrimination with HV protection shall be achieved; and
- Fuse-ratings shall be sufficient to cater for loads up to the thermal ratings of the distributors, which they protect.

The maximum LV fuse-link ratings for which discrimination is maintained across the associated distribution transformer, are shown in [Table 2](#).

**Table 2 – Distribution Transformer Maximum LV Fuse-Link**

DISTRIBUTION TRANSFORMER RATING (KVA)	PHASE	MAXIMUM ASSOCIATED LV FUSE-LINK RATING (A)
5	1	100 (Note 1)
10	1	100 (Note 1)
15/16	1	100
25	1	160
50	1	200
100	1	200
25	Split	100
50	Split	160
100	Split	200

200	3	200
300/315	3	315
500	3	400
750/800/1000	3	630

**Note 1) 100A is the smallest BS 88-2 fuse size fitted by Electricity North West. This will not provide overload protection for these 2 smallest transformer sizes.**

## 2.8 Earthing Arrangement

The earthing arrangements for the network shall be configured as follows.

- 11/6.6kV Network – Resistance Earth (maximum current 2200A).
- LV Network – Solid Earth (PME).

Further requirements for the earthing of distribution substations and equipment are described in EPD333, which shall be complied with by the application of the associated code of practice, CP333.

Detailed engineering requirements for the provision of LV PME connections are described in CP332.

## 2.9 Earth-Loop Impedance

The earth-loop impedance, as measured at any exit point, shall not exceed the values stated in ENA ER P23/1.

The earth-fault loop impedance at each cut-out shall be sufficiently small to pass fault current to operate the cut-out fuse within 5s. The earth-fault loop impedance at any cut-out should not normally be designed to exceed 0.35Ω on a CNE distributor and not to exceed 0.8Ω on any distributor.

## 2.10 Losses

The length of new HV connections to the existing Electricity North West network shall be kept to a minimum, so far as is reasonably practicable.

Distribution transformers shall comply with ES322, in particular, shall be of low-loss design.

LV networks designed in accordance with the requirements of this ES, in particular [2.9](#) and [2.11](#), can be expected to operate with an acceptable level of loss. However, the length of the LV network shall be kept to a minimum, so far as is reasonably practicable.

## 2.11 Loading of LV Networks

LV network design methods are described in CP226, which provides guidance on the After-Diversity Maximum Demand (ADMD) method. ADMD levels for new domestic dwellings may be assumed to be those shown in [Table 3](#).

**Table 3 – ADMD Levels for New Domestic Dwellings**

PROPERTY TYPE	ADMD PER CUSTOMER (KW)	
	Day	Night
Small Non-Electric Non-Detached	1.0	0.4
Non-Electric Detached	1.4	0.6
Electric Heating (installed in each of a group of average-sized properties). (This takes account of the large diversity, where electric heating is not subject to a restricted-hour tariff.) See 2.9.2 below regarding high density housing.	3.4	2.4
Two Rate Tariff, e.g. E7 (where substantial heating load is switched to take advantage of low 'restricted-hour' or 'off-peak' rates)	1.5	0.8 (aggregate installed 'restricted-hour' capacity kW) + 0.5
Off-peak Tariff with afternoon boost (where substantial storage heating load is switched to take advantage of low or 'off-peak' rates)	3.4	0.8 (aggregate installed water and storage heating capacity kW) + 0.5
Two Rate Tariff, e.g. E10 with afternoon, evening and night cheaper rates (where the tariff provides an incentive to concentrate usage in the cheaper periods, notably in the evening)	0.6 (maximum space heating available 07:00 to 24:00 plus water heating kW) + 2 *	0.6 (maximum space heating available 00:00 to 07:00 plus water heating kW) + 0.5 *
Air conditioning (where installed in each of a group of properties)	Taking account of the likely operating regime, it may be appropriate to add a fraction (say 50%) of the installed cooling load to the above daytime ADMD values.	
Heat Pumps and Electric Vehicles	As per EREC P5 and ES230	

Where electric heating, which is not subject to a restricted-hour tariff is to be used in high-density housing (e.g., flats), the ADMD figures given are to be used for all aspects of the electrical design except for the rating of distribution transformers. The ADMD contribution of such housing to the loading of transformers shall be taken as:

0.5(aggregate installed (fixed) space heating (kW) + 3kW water heating).

This is to take account of greatly reduced diversity in the event of a “cold-start” after a prolonged outage.

In this context, a transformer shall be taken to be feeding high-density housing, where 50% or more of its demand arises from electrically heated properties, without restricted-hour tariffs.

The three sizes of LV cable, permitted by the materials specification ES281 Part 2, are described in [Table 4](#). Newly installed LV distributors shall not be tapered, and underground distributors shall have a minimum cross-section of 300mm<sup>2</sup> SAC.

**Table 4 – Solid Aluminium Cored, Polymeric Insulated, Combined Neutral/Earth (CNE) Waveform Cable**

ALUMINIUM CORED, WAVEFORM CABLE CROSS- SECTION (mm <sup>2</sup> )	MAXIMUM CONTINUOUS RATING (A)		
	Laid Direct, Ungrouped Cable $g = 1.2\text{KmW}^{-1}$ $T_g = 15^\circ\text{C}$	In Ducts, One Cable Per Duct, Ungrouped Cable, $g = 1.2\text{KmW}^{-1}$ $T_g = 15^\circ\text{C}$	In Air & Shade, Ambient Temperature 25°C
95	235	190	230
185	335	275	350
300	435	360	475

The maximum voltage regulation from the LV busbars of a Distribution Substation to any exit point shall not exceed 7%, of which no more than 2% shall be in the service connection.

## 2.12 Disturbing Loads

Where it is known that equipment liable to cause disturbing voltage flicker is to be installed (e.g. instantaneous showers, heat pumps), distributors shall be designed such that the limits specified in ENA ER P28 are not exceeded.

## 2.13 Cable Layout

As far as is reasonably practicable, mains cables shall be laid in land adopted or to be adopted by the local authority under the New Roads and Street Works Act (NRSWA); cables shall be positioned in accordance with National Joint Utilities Group (NJUG) Guideline publications, Volume 1 and Volume 2.

All other routes for mains cables shall be secured by means of easements.

Mains cables shall not be laid nor left in position under any building.

Cables laid under carriageways shall be installed in continuous ducts.

As far as is reasonably practicable, mains cables to be adopted by Electricity North West shall be separated from those of other network operators, e.g. IDNOs. Where, however, it is expedient for Electricity North West's cables and other electricity cables to share the same route, Electricity North West's cables shall not be placed either above or below the other cables, except where cables need to cross each other.

## **2.14 Service Arrangement**

In new housing, services shall preferably be terminated on the external wall within small, medium or large sized meter cabinets complying with the requirements of BS 8567. The arrangement for service terminations is further described in ES213.

New connections shall, in accordance with CP332, be installed as PME.

Looped services are not permitted. All domestic services shall utilise the shortest practical route and shall be arranged in accordance with CP226.

Any service cable laid in private land shall be drawn into a continuous duct between the termination position and the adopted street or service strip. The duct shall take the shortest practicable route but shall not cross any third-party property.

Each meter point shall have its own means of isolation, by means of a sealable cut-out fuse.

Multiple service joints are permitted, connecting a maximum of four services each. In designing for the use of multiple service joints particular care shall be taken to balance the load on the main across the three phases.

## **2.15 Multiple Occupancy Buildings**

Connection arrangements for multiple occupancy buildings (flats, office blocks, industrial units etc) shall be in accordance with ES287, which describes the application of ENA ER G87 within the Electricity North West network.



### 3 Documents Referenced

DOCUMENTS REFERENCED	
<b>Legislation and Guidance</b>	
<b>NRSA</b>	New Roads and Street Works Act 1991
<b>NJUG Guidelines Volume 1</b>	Positioning and Colour Coding of Underground Utilities' Apparatus
<b>NJUG Guidelines Volume 2</b>	Positioning of Underground Utilities Apparatus for New Development Sites
<b>British Standards</b>	
<b>BS 88-2</b>	Low-voltage fuses. Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application). Examples of standardized systems of fuses A to K
<b>BS 8567</b>	Specification for outdoor electricity meter cupboards
<b>NOTE: Electricity North West is not able to supply copies of any of the above documents, but copies may be obtained from the British Standards Institution.</b>	
<b>Energy Networks Association Engineering documents</b>	
<b>ER G81 Part 1</b>	Framework for new low voltage housing development installations. Part 1 Design and planning
<b>ER G87</b>	Guidelines for the provision of low voltage connections to multiple occupancy buildings.
<b>ER P2/6</b>	Security of Supply
<b>ER P23/1</b>	Customers' Earth Fault Protection for Compliance with the IEE Wiring Regulations for Electrical Installations

<b>EP P25</b>	The Short-Circuit Characteristics of Public Electricity Suppliers' Low Voltage Distribution Networks and the Co-ordination of Overcurrent Protective Devices on 230V Single-Phase Supplies up to 100A
<b>ER P26</b>	The Estimation of the Maximum Prospective Short-Circuit Current for Three-Phase 415V Supplies
<b>ER P28</b>	Planning Limits for Voltage Fluctuations Caused by Industrial, Commercial and Domestic Equipment in the United Kingdom
<b>TS 35-1 Part 1</b>	Distribution transformers - Part 1 Common clauses
<b>NOTE: Electricity North West is unable to supply copies of any of the above documents, but copies may be obtained from the Energy Networks Association.</b>	
<b>Electricity North West documents</b>	
<b>EPD279</b>	Distribution System Design - General Requirements
<b>EPD282</b>	Distribution System Design - HV Network
<b>EPD283</b>	Distribution System Design - Low Voltage Network
<b>EPD333</b>	Supply System Earthing
<b>CP226</b>	Low Voltage Network Design
<b>CP331</b>	Protection of LV Underground and Overhead Distributors and HV Protection of Distribution Transformers
<b>CP332</b>	LV Service Connections and Application of PME
<b>CP333</b>	Earthing Design for 11/6.6kV Distribution Substations and Equipment
<b>ES210</b>	General Specification for Third-Party Constructed New Connections, Extensions and Alterations

<b>ES211</b>	Third-Party Provided New Connections of Street Electrical Fixtures
<b>ES212</b>	New whole-Current-Metered Connections up to 60kVA
<b>ES213</b>	Design of New Connections for Housing Developments
<b>ES214</b>	New LV Connections of up to 300kVA Capacity
<b>ES215</b>	New Connections of up to 1,500kVA Capacity
<b>ES216</b>	11/6.6kV Connections of up to 9MVA (6.6kV) or 15MVA (11kV) Capacity
<b>ES287</b>	Connections to Multiple Occupancy Buildings
<b>ES301</b>	Distribution Substation Housings; Replacement Roofs and Doors
<b>ES322</b>	Ground Mounted Distribution Transformers
<b>ES352</b>	Design of Distribution Substations

## 4 Keywords

ADMD; connection; design; domestic; ICP; P2/6; service.