

ENWLICE DG HV / EHV Workshop

5 March 2019

Stay connected...











www.enwl.co.uk

What do we want from you today?



- One word Feedback!
- Use the feedback forms and give us your honest opinion
- Contact me, the ICE team or your usual contacts in ENWL at any time to give us feedback
- mark.williamson@enwl.co.uk
- ice@enwl.co.uk



Domestic Arrangements



- Don't forget to sign in!
- No Fire Alarms planned
- Emergency Assembly Point
- WCs Fob on registration desk Please return
- Mobile Phones











Welcome & Introduction

ICE Workplan 2018-19 Update

ICE Workplan 2019-20 Development

Flexible Services

A&D Fees

Heat Map Tool

Coffee Break

Engineering Recommendation G99

Panel Question & Answer Session

Wrap Up & Close



ICE Update: DG HV EHV 2018-19 Workplan

Hannah Sharratt, ICE Manager

Stay connected...











www.enwl.co.uk

How are we performing against our commitments?



Commitment	How we'll achieve it	Delivery Date	Status
Improve connection charging approach to make charging fair for our customers	Engage with our stakeholders regarding our proposals	Q4	Complete
We will share our vision for the transition of Distribution Network Operators (DNO) to Distribution System Operators (DSO)	Hold an engagement session with our stakeholders	Q4	Complete
We will review our EHV connection offers	We will review our connection offers and introduce a new offer pack in line with ours and stakeholder needs.	Q2	Complete
We will improve visibility of remaining available capacity.	We will publish improved information on available thermal capacity and fault level.	Q2	Complete
Improve speed of response where transmission works required for a distribution connection	We will communicate the new process to customers, transition to the new process and publish the process	Q4	On Target

How are we performing against our commitments?



Commitment	How we'll achieve it	Delivery Date	Status
Develop and continue DG owner / operators panel	Hold 1 DG owner/operator forum session for generators at 33 /132kV	Q3	Complete
Target improved Time to Quote timescales for EHV quotations.	We will continue to work towards a 58 day average Time to Quote	Q4	On Target (YTD 57d)
Target improved Time to Quote timescales for HV quotations	We will continue to work towards a 58 day average Time to Quote	Q4	On Target (YTD 39d)
We will continue to offer opportunities for stakeholders to engage with us.	Offer surgery session and webinars and a workshop covering a range of topics.	Q4	On Target
Continue to provide quarterly updates on progress of actions	We will publish quarterly updates on our actions and outputs.	Q4	On Target



ICE 2019-20 Proposed Workplan

Hannah Sharratt, ICE Manager

Stay connected...











www.enwl.co.uk

Proposed DG HV EHV Workplan




How we created the proposed plan...



Draft 2019/20 ICE Workplan

2019-20 DG HV / EHV ICE Workplan Development





ICE Commitments League – Ranking exercise



- Using the sheets provided, please categorise each proposed ICE commitment.
 - Very important Into Europe
 - Important Mid table
 - Not very important Relegation zone





• List of Topics in proposed DG HV / EHV plan:

Network Capacity	Access to Geographical Information Systems	Engineering Recommendation G99
Flexible Services	Time To Quote	Outage communication
Flexible Connections	Time To Connect	Ofgem Charging Changes
DSO Transition	NMS – Pre Builts	Post acceptance process
Interactivity processes	Website	A&D Fees
Engagement	Regular updates	

Thank you!



Could you reduce demand or increase generation when instructed in return for payment?

Keith Evans
Smart Grid Engineer



Stay connected...

Figure 1...

Stay connected...

In the connected in the

Flexible Services



As the region's distribution network operator, it's our responsibility to plan for the future and seek out smarter, more flexible solutions to meet future demand for electricity. We are utilising a number of innovative techniques to ensure we can continue to deliver an affordable, reliable and sustainable electricity supply for all our customers.

Flexible services is one such technique

Distributed Energy Resources (DERs) are companies or individual customers capable of adjusting how much they consume or generate electricity. These adjustments can support the local distribution network due to high electricity demand or when the network is operating abnormally, and DERs receive payment from Electricity North West in return. These DERs can be generators, consumers, and electricity storage connected to our networks that can increase exports (generate more) or reduce imports (consume less) when instructed and receive payment in return.

We are looking to use this flexibility to support how we operate our local networks, as an alternative to traditional approaches. The aim is to reduce the cost for electricity distribution networks in customer energy bills while ensuring that our network remains resilient, reliable and meets our customers' needs.

Types of Flexible Service





RESTORE - Provide an immediate response following an unplanned network event



SUSTAIN - Flex your supply up or down at peak times to help manage network constraints



CONTINUOUS - Fulfil a continuous capacity requirement

Service Characteristics	RESTORE	SUSTAIN	CONTINUOUS		
When to Act	Post fault	Pre fault	Pre fault		
Trigger	Network abnormality	Asset loading	Constant		
Certainty of Utilisation	Uncertain	Uncertain	Certain		
Risk to network assets	High	Med	Low		
Frequency of use	Low	Med	High		

Current requirements



We are now regularly publishing our requirements for flexible services via Requests for Proposals (RfP's), and are looking for companies, customers or community groups who are capable of adjusting how much electricity they consume or generate.

There are three regions that we are actively seeking flexible services for currently.

The full RfP document for the three sites located in Cumbria will be published on our e-procurement portal WAX digital on 1st April.

For more information, or to register your interest for this RfP please visit our website at

www.enwl.co.uk/flexible-services



Forecast requirements





We have recently begun to publish our forecasted flexibility requirements on our website.

These are sites that we have identified as being constrained within the next five years, and that may be addressed by flexible services.

Please note that these are not guaranteed and are subject to future capacity reviews.

To receive notifications of new flexible service requirements, please sign up to our distribution list at www.enwl.co.uk/flexible-services.



Upcoming DFES Webinar

Keith Evans

Smart Grid Engineer

Stay connected...

















Sign up to our webinar and find out how we're preparing for the future of electricity in the North West



11.00am - 12.00 noon, Thursday 28 March 2019



www.enwl.co.uk/dfes



Connections Offer Expenses -Update

Brian Hoy, Head of Market Regulation and Compliance

Stay connected...












www.enwl.co.uk



BEIS introduced new regulations from April 2018

These allow DNOs to charge customers for their connection offer whether it is accepted or not

BEIS intention is to allow a fairer allocation of costs to customers



What do we propose to charge for?



What we won't be charging for

Budget Estimates

Minor connections (1-4)

Cancellations within cooling off period

Offers for diversions

What we will be charging for

EHV offers (demand and generation) from May 2018

HV generation offers over 1MVA from January 2019

LV and other HV offers (demand and generation) but from a later date

Requotes including interactivity requotes

Cancellations (after cooling off period)

Gen+ initial assessments

These charges will be due whether the connection offer is accepted or not



Customer Application

Connection Offer issued Connection
Offer validity
period

Acceptance

Email informing customer is liable for payment for quote but with 10 working day cooling off period

Connection offer issued together with invoice for £1,000 with 30 day payment terms

Quote validity
period normally
180 days but will
end after 30 days if
invoice not paid

Customer pays
balance of
Connection Offer
Expenses if they
accept as part of
Acceptance Fee



Four different options available to you for EHV offers and HV generation over 1MVA

Budget Estimate

Gen +

Full Works Offer

POC Only Offer

- No charge
- Can't accept
- No queue position
- •Initial charge of £500 payable in advance
- •Further charge of £1,000 for full offer
 - Queue position retained

- Initial charge of £1,000 (Dual Offer)
- •Balance based on type of acceptance:
- £20,200 EHV full works
- •£15,800 EHV POC only
- •£5,870 HV gen full works
- •£4,500 HV gen POC only

- •Initial charge of £1,000 for connection Offer
- Balance based on type of acceptance:
- •£15,800 EHV POC only
- •£4,500 HV gen POC only

EHV applicable from 4 May 2018

HV Generation greater 1MVA applicable from 1 January 2019

Network Information Heat Map Tool

Gill Williamson



Bringing energy to your door



Stay connected...











www.enwl.co.uk



New Heat Map Tool launched 28 January 2019

Identifies nearest substations

Indicates the ability to make connection there

Accompanied by maps of substation locations

Download here: https://www.enwl.co.uk/get-connected/network-information/heatmap-tool/

- Does not replace detailed assessments
- •Indication of constraints doesn't mean that we can't connect you



Excel Workbook

Tools

Background Data

User Guide and Network Maps

11kV & 6.6kV Connections

33kV Connections

Primary Headroom Data BSP Headroom <u>Dat</u>a Transmission Capacity

Workbook Tabs

Heat Map Tool – Tab 1) User Guide and Network Maps





User Guide

With this tool we aim to provide our customers with information on where there is spare capacity for new developments to connect to our network without triggering reinforcement work. To aid our customers in interpreting the information contained within this tool we have produced a user guide which can be found below. Please note that the data presented in this tool is based on high level analysis and as such may differ from the results of a formal connection application.

If your proposed development falls within an area with limited network capacity please contact us to discuss a possible solution.

We will always to work with customers to overcome network constraints whether this is through traditional reinforcement or smart network solutions.



25.01.2019

Map Data

The maps below provide the customer with an overview of the location of key assets:








Last Undated:



Maps of BSP & Primary substation locations and roads



Heat Map Tool –Tabs 2 & 3) 11kV & 6.6kV & 33kV Connections





11 kV & 6.6 kV Connections

The results given by this tool are based on high level approximations only. It should also be noted that the network since the last time the data was updated. As such, the outcome of a formal application may differ from the results given by this tool. For further information on how to intermined within this workbook please refer to the user guide embedded within the first tab.

Inputs		
Easting	Enter Data	
Northing	Enter Data	7
Scheme Capacity (MW)	Enter Data	
Connection Type	Enter Data	

the controls to the left to find the nearest primary substations to your site. The results will be displayed in the table below. When the desired site capacity and connection type are entered an estimate of available headroom and connection feasibility will be displayed. The results are based on both local constraints and constraints at the associated BSP.

Results											
No	Distance (km) Primary Substation		BSP Group	GSP Group	Primary Subst	ation Location	Headroom (MM)	Can be accommodated? (RAG)			
140	Distance (Kill)	Filliary Substation	DOF GIOUP	dar droup	Easting	Northing	ricadiooni (ivivv)	can be accommodated. (NAC)			
1	0.34	TRINITY	FREDERICK RD	KEARSLEY	382649	398230	0.0				
2	0.63	BLACKFRIARS	FREDERICK RD	WHITEGATE	383030	399104	4.1				
3	0.66	CHAPEL WHARF	FREDERICK RD	KEARSLEY	383499	398634	8.3				
4	0.71	DEANSGATE	BLOOM ST	SOUTH MANCHESTER	383463	398149	6.6				
5	0.83	KNOTT MILL	BLOOM ST	SOUTH MANCHESTER	383136	397725					
6	1.12	BRIDGEWATER	BLOOM ST	SOUTH MANCHESTER	A						
7	1.22	CANNON ST	RED BANK			220003	5.1				
8	1.43	FREDERICK RD	FREDERICK RD		381697	399348	10.2				
9	1.48	DICKINSON ST	BLOOM ST	SOUTH MANCHESTER	384109	397722	0.0				
10	1.55	STRANGEWAYS	RED BANK	WHITEGATE	383780	399743	5.1				

Connection Types	
Demand Firm	The connection of load which is secure for a first circuit outage.
Demand N-0	The connection of load which can be actively constrained off under outage conditions
Generation Synchronous (LV)	Generation such as diesel or gas turbines connected to the HV network through step up transformers.
Generation Synchronous (HV)	Generation such as diesel or gas turbines connected to the HV network directly i.e. without step up transformers.
Generation Inverter Based	Generation technologies connected by inverters this typically includes solar and wind generators
Battery Energy Storage	Inverter connected battery energy storage schemes

User enters connection requirements:

- Grid co-ordinates
- Required capacity
- Connection type
- i.e. Demand or generation

Results

- Nearest Primaries/BSPs
- •Headroom
- •Can be accommodated? (RAG)

Heat Map Tool – Tabs 4 & 5) Primary & BSP Headroom Dat





BARTON DOCK RI

Primary Substation Hea	droom										
				Primary Substation Location		Demand Headroom (MW)		Generation Headroom N-0 -(MW)			Battery Storage
Primary Substation	on Voltage (kV) BSP Group	GSP Group	Easting	Northing	Firm	N-0	Inverter Based	Synchronous - LV	Synchronous - HV	Headroom N-0 -(MW)	
ALBION ST	6.6	LOWER DARWEN	ROCHDALE	367434	426087	0.0	13.7	0.0	0.0	0.0	0.0
ALDERLEY	11	MOSS NOOK	SOUTH MANCHESTER	385044	379026	7.8	14.8	11.2	2.0	1.4	11.2
ALSTON	11	PENRITH & SHAP	HARKER / HUTTON	372125	546499	0.0	0.0	3.7	3.7	3.7	0.0
AMBLESIDE	11	KENDAL (PARKSIDE RD)	HARKER / HUTTON	337602	503506	7.5	16.7	0.0	0.0	0.0	0.0
ANCOATS NORTH T11 & T12	6.6	RED BANK	WHITEGATE	385022	398830	0.0	1.2	32.2	6.9	5.0	1.2
ANCOATS NORTH T14	6.6	RED BANK	WHITEGATE	385032	398840	0.0	5.1	20.0	20.0	16.0	5.1
ANNIE PIT	11	STAINBURN & SIDDICK	HARKER / HUTTON	300011	527810	2.4	6.9	0.0	0.0	0.0	0.0
ANSDELL	6.6	LYTHAM	PENWORTHAM WEST / STANAH	334416	428229	7.1	10.1	21.6	10.2	7.4	10.1
ARDWICK	6.6	STUART ST	STALYBRIDGE	384753	397415	0.0	1.3	24.2	14.1	10.3	1.3
ARNSIDE	11	KENDAL (PARKSIDE RD)	HARKER / HUTTON	346495	478180	9.7	13.4	0.0	0.0	0.0	0.0
ASHTON (GOLBORNE)	6.6	GOLBORNE	BOLD	357056	400663	0.3	7.8	0.0	0.0	0.0	0.0
ASHTON (RIBBLE)	6.6	RIBBLE	PENWORTHAM EAST / ROCHDALE	350275	430526	3.1	3.1	10.5	2.0	1.4	3.1
ASHTON ON MERSEY	6.6	SALE	CARRINGTON	377188	392252	9.9	14.0	28.8	9.2	6.7	14.0
ASHTON UNDER LYNE T11 & T12	6.6	HARTSHEAD-HEYROD	STALYBRIDGE	393275	399319	4.4	8.5	7.0	2.0	1.4	7.0
ASHTON UNDER LYNE T13	6.6										
ASHWOOD DALE	6.6										
ASKAM	11	electi north u	ricitu								
ASKERTON CASTLE	11	north u	uest -								
ASPATRIA	11										
ATHERTON TOWN CENTRE	11	Bringing energy	10 9001 0001								

BSP Headroom

Background Primary & BSP Headroom Data

Basis of the previous tools

•Considers:

- Network thermal capacity
- Fault levels
- Existing demand and generation
- Accepted demand and generation

			BSP Coordinates Demand Headroom (MW)			Generation nead	room - N-0 -(MW)	Battery Storage Headroom	
BSP	Voltage (kV)	GSP Group	Easting	Northing	Firm	Non Firm	Inverter Based	Synchronous	N-0 -(MW)
ADSWOOD	33	BREDBURY	389188	388310	55.6	73.6	150.1	54.1	73.6
AGECROFT	33	KEARSLEY	380345	401831	14.5	26.5	90.4	25.4	26.5
ALTRINCHAM	33	CARRINGTON	376380	389012	47.5	65.5	151.5	46.4	65.5
ATHERTON	33	KEARSLEY	366150	402088	19.2	37.2	94.5	17.1	37.2
BARROW	33	HARKER / HUTTON	319709	470489	39.4	79.4	80.2	14.5	79.4
BARTON	33	CARRINGTON	376758	397174	46.7	76.7	6.7	1.9	6.7
BELFIELD	33	ROCHDALE	391033	413945	55.3	74.9	54.7	12.9	54.7
BISPHAM	33	PENWORTHAM WEST / STANAH	332328	439711	33.9	51.9	40.6	7.4	40.6
BLACKBURN	33	PENWORTHAM EAST / ROCHDALE	370584	429294	60.0	77.6	84.4	36.6	77.6
BLACKPOOL	33	PENWORTHAM WEST / STANAH	330835	435308	28.6	46.6	36.9	6.7	36.9
BLOOM ST	33	SOUTH MANCHESTER	384221	397717	0.0	10.4	160.0	45.8	10.4
BOLTON	33	KEARSLEY	372255	410566	18.3	37.3	10.7	1.9	10.7
BURNLEY	33	ROCHDALE	385569	434469	58.1	76.1	10.7	1.9	10.7
BURY	33	KEARSLEY	380272	411184	23.9	23.9	10.7	1.9	10.7
BUXTON	33	STALYBRIDGE	407769	375476	0.0	48.3	10.7	1.9	10.7
CARLISLE	33	HARKER / HUTTON	338655	556583	7.6	28.6	6.7	1.9	6.7
CARRINGTON BSP	33	CARRINGTON	373110	393020	21.6	51.6	0.0	0.0	0.0
CASTLETON	33	ROCHDALE	388461	411290	19.9	58.9	122.6	23.0	58.9
CHADDERTON	33	WHITEGATE	389137	403821	10.5	10.5	98.3	17.8	10.5
DROYLSDEN	33	STALYBRIDGE	390140	398146	42.1	60.1	10.7	1.9	10.7
EGREMONT	33	HARKER / HUTTON	301070	513074	68.1	76.1	97.5	58.7	76.1
FREDERICK RD	33	KEARSLEY	381795	399250	0.0	10.2	6.7	1.9	6.7
GOLBORNE	33	BOLD	360607	397690	3.7	18.7	0.0	0.0	0.0
GREENHILL	33	WHITEGATE	393262	404755	31.3	31.3	38.5	7.0	31.3
HAZEL GROVE	33	BREDBURY	391313	386877	37.7	55.7	100.3	18.2	55.7
HARTSHEAD-HEYROD	33	STALYBRIDGE	397322	399942	27.4	84.4	6.7	1.9	6.7
HUNCOAT	33	PADIHAM	377997	431083	37.1	55.1	31.5	5.7	31.5
HYDE	33	STALYBRIDGE	395522	395647	53.8	71.8	10.7	1.9	10.7
KEARSLEY LOCAL	33	KEARSLEY	376355	404783	9.4	52.4	6.7	1.9	6.7
KENDAL (PARKSIDE RD)	33	HARKER / HUTTON	351915	491858	9.7	27.7	0.0	0.0	0.0
LANCASTER	33	HEYSHAM	348644	463628	25.7	25.7	10.7	1.9	10.7
LEYLAND	33	PENWORTHAM WEST / STANAH	354121	423373	25.1	43.1	0.4	0.1	0.4

Heat Map Tool – Tab 6) Transmission Capacity





Appendix G Summary											
GSP / Site	Capacity o	f Connected & Co	ontracted Connec	tions (MW)	Materiality Headroom	Materiality	Capacity in Project Progression /	Total Capacity of Connections	Transmission FL Headroom		
	Part 1	Part 2	Part 3	Part 4	(Part 5) (MW)	Status	Modification Application	(MW)	(kA)		
Rainhill / Bold (Golborne)*	25.1	50.0	0.0	0.0	0	В	N/A	75.1	0		
Bredbury	10.1	86.3	0.0	0.0	50	Α	N/A	146.4	3		
Carrington	105.0	233.0	0.0	0.0	0	В	N/A	338.0	3		
Harker	671.0	123.7	0.0	143.9	0	С	143.9	938.6	0		
Hutton	49.0	10.4	0.0	104.5	0	С	104.5	163.9	0		
Heysham	302.0	0.0	0.0	133.6	0	С	133.6	435.6	0		
Kearsley & Kearsley local	57.4	237.5	0.0	0.0	0	В	N/A	294.9	0		
Kirkby	6.0	115.9	0.0	0.0	0	В	N/A	121.9	3		
Macclesfield	27.9	20.0	0.0	0.0	50	Α	N/A	97.9	3		
Padiham	35.5	139.9	0.0	0.0	50	Α	N/A	225.4	0.98		
Pen East Roch / Pen West	189.6	709.1	0.0	0.0	0	В	N/A	898.7	3		
Rochdale Main Part	204.7	158.2	0.0	0.0	50	Α	N/A	362.9	3		
South Manchester	22.2	109.9	0.0	0.0	50	Α	N/A	182.1	0.5		
Stalybridge	58.0	293.0	0.0	0.0	50	Α	N/A	401.0	0.78		
Stannah	195.9	59.5	0.0	0.0	0	В	N/A	255.4	0.64		
Washway Farm	14.2	131.2	0.0	0.0	0	В	N/A	145.4	3		
Whitegate	32.0	187.0	0.0	0.0	0	В	N/A	236.9	0		

Appendix G Summary

Lists all ENWL GSPs

•Indicates:-

- Existing generation connections
- Constrained generation connections
- Future generation connections
- Thermal headroom
- Fault level headroom



The new heat map tool provides:-

Better quality information

Improved accuracy

Monthly refresh rate

Coffee break







EREC G99

Steffan Jones / Gill Williamson

Stay connected...











www.enwl.co.uk

EREC G98 & EREC G99




G98:

Requirements for the connection of Fully Type Tested **Micro-generators** (up to and including 16 A per phase) in parallel with public Low Voltage Distribution Networks on or after 27 April 2019

PRODUCED BY THE OPERATIONS DIRECTORATE OF ENERGY NETWORKS ASSOCIATION Engineering Recommendation G98 Issue 1 - Amendment 1 16 May 2018 Requirements for the connection of Fully Type Tested Micro-generators (up to and including 16 A per phase) in parallel with public Low Voltage Distribution Networks on or after 27 April 2019 www.energynetworks.org

G99:

Requirements for the connection of generation equipment in parallel with public distribution networks on or after 27 April 2019





Present summary of EREC G99

Explain your and our responsibilities under EREC G99

Discuss the connection timeline under EREC G99

EREC G99 Terminology






EREC G99 - Types (GB)



•Types affect technical requirements and which forms you use




EREC G99 - Power Generating Units & Power Generating Modules




Types depend on PGM capacity

PGM definition depends on whether the technology is synchronous / asynchronous

SYNCHRONOUS SCHEME



ASYNCHRONOUS SCHEME



Generating Unit, GU


Power Generating Module, PGM

Power Generating Facility, PGF

EREC G99 – Type A synchronous machine example



3 x 400 kW Type A Synchronous PGMs = 1.2 MW PGF



Power Generating Module (PGM) / Synchronous Power Generating Module


Power Generating Facility (PGF)

EREC G99 – Type B asynchronous example



1 x 400 kW Inverter connected plus 2 x 400 kW Asynchronous GU

= 1.2 MW Type B PPM = 1.2 MW PGF



Power Generating Module (PGM) / Power Park Module (PPM)

Power Generating Facility (PGF)

EREC G99 – Type A and Type B Power Generating Modules in same Power Generating Facility


★■★★

3 x 4MW Type B synchronous PGMs

2 x 500 kW Inverter connected plus 1 x 500 kW Asynchronous GU = 1.5 MW Type B PPM

1 x 1MW Energy Storage = 1MW Type B PGM

= 14.5MW PGF



Power Generating Module (PGM) / Synchronous Power Generating Module

Power Generating Module (PGM) / Power Park Module (PPM)

Power Generating Facility (PGF)

EREC G99 – Standard Application Form, SAF





Used when wanting to connect a Power Generating Module greater than 16 Amps per phase.

Changes include:-

- Alignment of terminology with G99 (PGM, GU etc)
- Inclusion of storage data
- New technical data
 - Voltage control data
 - Frequency response droop settings
 - •Type C & D only:
 - Governor and prime mover model
 - AVR and excitation model
 - Short circuit ratio

Connection of Power Generating Modules to DNO Distribution Networks in accordance with EREC G99

Version 2, January 2019

www.energynetworks.org

Can be accessed from our website: https://www.enwl.co.uk/get-connected/new-connection/generation-connection/over-200kw/

EREC G99 – Power Generating Module Document, PGMD



ENA Engineering Recommendation G99 Issue 1 Amendment 3 2018

Power Generating Module Document Type B

Form B2-1 Power Generating Module Document for Type B Power Generating Modules Compliance Statement This document shall be completed by the Generator				
			Power Generating Module (PGM)	<u>Distribution Network</u> <u>Operator (DNO):</u>
			PGM Name:	DNO Name: ABC electricity distribution
Compliance Contact (name/tel/email):	Compliance Contact (name/tel/email):			

A - Application: Submission of the Standard Application Form.

IS - Initial Submission: The programme of initial compliance document submission to be agreed between the Generator and the DNO as soon as possible after acceptance of a Connection Offer. Initial Submission of this Power Generating Module Document to be completed at least 28 days before the Generator wishes to synchronise its Power Generating Module for the first time.

FONS - Final Operational Notification Submission: The Generator shall submit post energisatio verification test documents to obtain Final Operational Notification from the DNO.

Key to evidence requested	Key to Compliance	
S - Indicates that DNO would expect to see the results of a simulation study	Y = Yes (Compliant),	
P - Generating Unit or Power Generating Module design data	O = Outstanding (outstanding submission)	
MI - Manufacturers' Information, generic data or test results as appropriate	UR= Unresolved issue	
	N = No (Non-Compliant)	
D - Copies of correspondence or other documents confirming that a requirement has been met	, , ,	
T - Indicates that the DNO would expect to see results of, and/or witness, tests or monitoring which demonstrates compliance		
TV - Indicates Type Test reports (if Generator pursues this compliance option)		

= Compliance Statement

Type B – form B2-1 (appendix B of EREC G99) Type C & D – form C2-1 (appendix C of EREC G99)



Notifications issued by the DNO to a Generator

Final Operational Notification (FON)

Issued when the relevant requirements of EREC G99 are complied with allowing operation of the PGM in parallel with the distribution network.

Type D only:

Energisation Operational Notification (EON)

Issued prior to energisation of a generator's internal network.

Interim Operational Notification (ION)

Issued to permit time limited synchronisation when there are outstanding compliance issues.

EREC G99 – Manufactures Information



Manufacturers' Information is the generic term for information that the Generator needs, which needs to be sourced from the manufacturer. It can include type testing information, but also other relevant information that does not necessarily come from type tests, e.g. simulation studies etc.

The information is supplied by the manufacturer to the customer, who should send it to the DNO. The suitability of the information is agreed between the generator and the DNO – although a three way discussion involving the manufacturer might well be appropriate in some cases.

A manufacturer might have posted this information on the ENA database, in which case it will have an ID reference. The generator can use the ID reference in compliance forms.

Changes to the connection process







Applies to:-

New generator connections >800kW,

Electricity Storage, but some technical requirements do not apply

All types of electrical conversion machines and equipment

Generators significantly revised or replaced after 27 April 2019

Exempt:-

Generators connected before 27 April 2019



Now

Information Phase

Design Phase

Connection Offer

Connection Acceptance

Compliance Checking

Construction Phase

Energisation/Commissioning

From Generator Concept to Connection

After 27 April 2019

Information Phase

Design Phase

Connection Offer

Connection Acceptance

Compliance Checking

Construction Phase

Energisation/Commissioning

Final Compliance Check

Operational Notifications

Chansing

EREC G99 - Connection Process



Looking at the connection new process in terms of....



Design Phase

Connection Offer

Connection Acceptance

Compliance Checking

Construction Phase

Energisation/Commissioning

Final Compliance Check

Operational Notifications

Timeline





EREC G99 Connection Process - Design Phase



Connection Process

Information Phase

Design Phase

Connection Offer

Connection Acceptance

Compliance Checking

Construction Phase

Energisation/Commissioning

Final Compliance Check

Operational Notifications

Timeline

Offer issued after submission in accordance with GSOP timescales



Generator submits
SAF



Design Phase G99 Documents

Standard Application Form

EREC G99 Connection Process Design Phase – Submission of SAF

- 費
- •Form A1-1 for Type A fully type tested <50kW 3-phase (17kW 1-phase)
- •SAF >50kW 3-phase
 - •Different parts submitted at different times
 - •Different parts for different technologies
 - Part 1 Contact details, location and operational information
 - Part 1a Supplementary contact details
 - **Part 2** Power Generating Facility general data
 - Part 3 Power Generating Module model data

Initial Submission

- **Part 4a Synchronous Power Generating Modules**
- Part 4b Power Park Module model data: Fixed speed induction Generating Units
- Part 4c Power Park Module model data: Doubly fed induction Generating Units
- Part 4d Power Park Module model data: Series inverter connected Generating Units
- Part 4e Power Park Module model data: Electricity Storage plant
- **Part 4f Transformer information**
- Part 5 Additional data which may be required by the DNO

Prior to Synchronising

EREC G99 Connection Process - Compliance Checking



Connection Process

Information Phase

Design Phase

Connection Offer

Connection Acceptance

Compliance Checking

Construction Phase


Energisation/Commissioning

Final Compliance Check

Operational Notifications

Timeline

From time of acceptance to prior to energisation



- Generator & DNO agree compliance submission programme
- ➤ Generator iteratively submits their PGMD & associated evidence
- DNO reviews & responds / repeat



Compliance Checking Documents

- Power Generating Module Document
- Generator's compliance evidence (Simulation reports, Manufacturers Information, Type Testing reports)



Technical requirements vary with Type

Generators can choose how they demonstrate compliance

Compliance is tracked in the PGMD

Incl. manufacturer info, type testing, simulation and site commissioning

DNO approval is required

EREC G99 Connection Process - New / Modified Technical Requirements



Interface Protection Settings (Types A, B, C & D)

DNO logic interface by which generator will reduce active power (Type A)

DNO communication interface for reducing active power (Types B, C & D)

Frequency withstand (Types A, B, C & D)

Rate of change of frequency withstand (Types A, B, C & D)

Minimum active power at low frequency (Types A, B, C & D)

Limited frequency sensitive mode – over frequency (Types A, B, C & D)

EREC G99 Connection Process - New / Modified Technical Requirements



Fault ride through (Types B, C & D)

Voltage / power factor control capability (Type B, C & D)

Reactive Power Capability (Types B, C & D)

Fast fault current injection (Types B, C & D Power Park Modules)

Low frequency sensitive mode – under frequency (Types C & D)

Frequency sensitive mode (Types C & D)

Operational Monitoring (Types C & D)

EREC G99 Connection Process - Energisation/Commissioning

黄圆黄黄

Connection Process

Information Phase

Design Phase

Connection Offer

Connection Acceptance

Compliance Checking

Construction Phase

Energisation/Commissioning

Final Compliance Check

Operational Notifications

Timeline

Immediately before operation



Energisation / Commissioning Activities

Generator undertakes site commissioning tests for remaining compliance requirements

>DNO witnesses tests



Energisation / Commissioning Documents

- Commissioning forms (B2-2 & C2-2)
- •Installation forms (B3 & C3)

EREC G99 Connection Process Compliance forms – Type A



•For Type A, the form depends on the use of type testing

Type A	Manufacturer's Information	Site Tests
Fully Type Tested	No specific form Reference is made in the installation form to the registration on ENA website	Form A2-4 completed if site compliance tests are being undertaken for some or all of Type A generator
Partially Type Tested	Form A2-1 Synchronous PGM ≤50kW Form A2-2 Synchronous PGM >50kW Form A2-3 Inverter connected PGMs	Interface Protection where it is not Type Tested Installation forms: Form A3-1 Type A PGMs From A3-2 Integrated micro generation and storage

EREC G99 Connection Process Compliance Checking— use of the PGMD

- Record of compliance evidence
- •PGMD is likely to be iterative as the generator submits evidence of compliance and the DNO reviews it.

Page 1 PGM and DNO basic information
Page 2 PGMD version control / PGM details

General information

Pages 3 – 7 Synchronous Power Generating Module compliance requirements

Pages 3-4 submitted at Initial Submission

Pages 5-7 submitted at FONs – post energisation verification test documents

Pages 8 – 12 Power Park Module compliance requirements
Pages 8-10 submitted at Initial Submission
Pages 11-12 submitted at FONs – post energisation verification test documents


EREC G99 Connection Process Compliance check – Commissioning form

•B2-2 & C2-2: completed if site compliance tests are being undertaken in the absence of other evidence for Types B, (C&D) respectively.

Page 1
PGM basic information
Information
Summary table indicating compliance by
Manufacturers Information or commissioning tests

Pages 2 – 5
Results tables for each type of test

Results



EREC G99 Connection Process Compliance check – Installation form © Compliance and Commissioning test requirements. •B3 & C3: completed as a record of commissioning and installation for Types B, (C&D) respectively. Part 1 Installer Per PGF **Installation details PGF** commissioning information Manufacturers Information or bype Part 2 Per PGM **PGM** commissioning information **Generator Declaration Declarations**

DNO Declaration

EREC G99 Connection Process - Final Compliance Check



Connection Process

Information Phase

Design Phase

Connection Offer

Connection Acceptance

Compliance Checking

Construction Phase

Energisation/Commissioning

Final Compliance Check

Operational Notifications

Timeline

Immediately before operation



Final Compliance Check Activities

Final PGMD,
Installation &
Commissioning forms



Energisation / Commissioning Documents

- PGMD
- Commissioning forms (B2-2 & C2-2)
- Installation forms (B3 & C3)

EREC G99 Connection Process - Operational Notifications



Connection Process

Information Phase

Design Phase

Connection Offer

Connection Acceptance

Compliance Checking

Construction Phase

Energisation/Commissioning

Final Compliance Check

Operational Notifications

Timeline

At time of operation



- DNO confirms all commissioning tests completed and data submitted
- DNO issues FON
- PGM is allowed to operate using the distribution network



Operational Notification Documents

• FON

EREC G99 Discussion









FAQs on website



Webinars



Individual bespoke sessions

EREC G99 - Further information



➤ Electricity North West Website

https://www.enwl.co.uk/get-connected/new-connection/generation-connection/engineering-recommendation-g99

> ENA Website

http://www.energynetworks.org/electricity/engineering/distributed-generation/engineering-recommendation-g59.html

> DG Connection Guides

http://www.energynetworks.org/electricity/engineering/distributed-generation/dg-connection-guides.html

Distribution Code DPC7

covers requirements for embedded generators including G99

http://www.dcode.org.uk/





1) Do you now know what is expected of you?

- 2) Is there anything that is still unclear for you?
- 3) Have you thought about how you are going to submit your evidence?
- 4) Is there anything more that you think we can do to help?

Panel Q & A







Wrap up and Close

Mark Williamson

Energy Solutions Director

Stay connected...













www.enwl.co.uk

Wrap Up & Close



Please give us your honest feedback on the forms provided



Presentation slides will be available via our website at the latest early next week.

Don't forget to get in touch with us at ICE@enwl.co.uk



Thank you for your attendance and have a safe journey home.