



Distributed Generation HV & EHV Workshop

4 March 2020

Stay connected...



www.enwl.co.uk



Welcome and Introduction

Steffan Jones

Stay connected...



www.enwl.co.uk

Domestic Arrangements



- Don't forget to sign in!
- Toilets situated in main reception area
- Planned fire alarm test at 3pm
- Floor plans highlight evacuation point
- Emergency Assembly Point – Hartington Road
- Mobile Phones
- Photography will be taken during the event



What do we want from you today?



- One word – **Feedback!**
- Use the feedback forms and give us your honest opinion
- Contact the ICE team or your usual contacts in ENWL at any time to give us feedback
- ice@enwl.co.uk





Agenda

Welcome &
Introduction

Accessing the Network & Network Information

Lunch & Networking 12 – 12:45

ICE Update &
Shaping our 2020-21
Workplan

Coffee Break

Engineering
Recommendation
G99

Question &
Answer
Session

Wrap Up &
Close

Meet the Team



Steffan Jones



**Head of Infrastructure
Solutions**

Steffan joined Electricity North West in 2014 as the Infrastructure Solutions Manager, heading up both the Grid and Primary Connections team and the Asset Diversions team. During his 24 year career he has worked in both heavy industry and commercial contracting roles as well as the electrical utility sector. Steffan aims to enhance the customer journey throughout the delivery of Infrastructure Solutions projects.

Victoria Brown



Bid Engineer

Victoria joined Electricity North West in 2014 after graduating from university. As a Bid Engineer within the Grid and Primary Bid Team, Victoria is responsible for estimating and quoting Generation Connections >1MW.

Brian Hoy



**Head of Market
Regulation**

Brian has over 30 years of experience working in the electricity industry. He has an engineering background but has worked in the regulatory aspects of new connections for a number of years. Brian represents Electricity North West on connections related matters and leads a number of national industry groups.

Gillian Williamson



HV Planning Manager

Gill's role in Strategic Planning includes managing the team responsible for HV connections, providing technical support to our customers from identification of least cost points of connection through post acceptance including protection reviews, fault level studies, power quality assessments and earthing.

Meet the Team



Hannah Sharratt



**Connections Stakeholder
Engagement and
Regulation Manager**

Hannah has 20+ years experience in the Utility industry in programme, project and change management roles. Hannah is currently focusing on our Connections stakeholder engagement activity and is committed to delivering real and lasting enhancements to our stakeholder experience.

Ami Mathieson



**Incentive on Connections
Engagement Manager**

Ami joined Electricity North West 9 years ago; she has spent that time primarily within the Customer directorate. Her current role is to support the Connections Stakeholder Engagement and Regulation Manager in the successful delivery of the Incentive on Connections Engagement (ICE) strategy and aims.

John Carlisle



**Infrastructure Solutions
Programme Manager**

John is the Delivery Programme Manager for our Grid and Primary Connections team. John is an Incorporated Engineer with the Institute of Engineering and Technology and a Registered member of the Association of Project Management. John and his team are responsible for the delivery of all new connections on the 33KV and 132KV networks, inclusive of all demand and generation projects.

Matt Savka



**Connections Delivery
Manager**

Matt joined Electricity North West over 14 years ago. During this time he has worked in several different roles within Connections, from Design Engineer to Business Connections Manager. Matt's current focus is on design for demand and generation connections in the south of our region.

Meet the team



Peter Barlow



**Programme Manager-
Grid and Primary**

Peter joined Electricity North West in 2017 as a Programme Manager for Infrastructure Solutions. He leads the Bid Team within Grid and Primary connections. His background is in Mechanical Engineering, previously working in Energy Markets as a Sales Manager in Oil & Gas, and Offshore Renewables (Wind, Wave, and Tidal Power).

Tracey Taylor



**Delivery Manager-
Business Connections
Lakes**

Tracey joined Electricity North West 31 years ago with a background in Design. She currently works within the Business Connections team as Construction and Delivery Manager responsible for delivering Generation and Demand Connections at LV and HV within the North area, with a focus on the delivery stage. Tracey ensures the team are managing the construction and energisation of connections in line with customer expectations.

Joe Davis



Project Planner

Joe joined the new connections team in Electricity North West in 2002. Joe has developed from assisting customers with small industrial connections to assisting them with larger connections, facilitating them with all aspects of the journey including generation, constrained connections, fault level studies, protection studies, earthing assessments, project management and final commissioning works.



Accessing the Network and Network Information

Victoria Brown, Steffan Jones, Gill Williamson, Brian Hoy,
Hannah Sharratt

Stay connected...



www.enwl.co.uk



Getting Connected

What We Offer

Network Constraints

- Distribution Constraints
- Transmission Constraints

Pre Application Contact

Interactivity

Network Information

Heat Map Tool

Other Potential Information
Sources

GIS Update

Transition to DSO and Flexibility

DSO Transition

Flexible Services

Flexible Connections



Getting Connected

Victoria Brown

Stay connected...



www.enwl.co.uk

What do we offer?



Budget

Formal Offer

Gen Plus

Advantages

- No Cost Associated
- Short timescales- max 20 working days
- Gives an early indication whether a connection will be cost prohibitive

Disadvantages

- High Level Desktop Assessment – Network Modelling is not undertaken
- Cannot be accepted or progressed to a Formal Application – no ability to retain start date

Advantages

- Open to Acceptance – secure capacity for the requested technology and size
- Network Modelling is undertaken to determine the impact on the ENWL network

Disadvantages

- Fee of £1,000 + VAT
- Maximum timescale of 65 working days to issue the Offer
- No early indication of viability/cost of the requested connection

Advantages

- Budget letter within 30 working days, early indication whether the connection is viable
- Network assessment undertaken for the budget element
- Up to 6 options (export/technology) for one site
- Start date is retained for the formal offer if pursued within 7 days

Disadvantages

- Fee of £500 + VAT for the budget assessment
- Then a further £1,000 + VAT if progress to a Formal Application



There are a number of common constraints that can be encountered across the ENWL network, which can have an impact on Connection Applications, either by requiring Reinforcement or changing the Point of Connection.

Fault Level

- All generation has some FL contribution – Synchronous generation will contribute more than Asynchronous
- Can potentially be mitigated by ENWL or by the Generator
- POC will be discounted if the proposed DG causes a FL exceedance

Thermal Capacity

- Thermal constraints arise where the Network has insufficient capacity to accommodate the requested generation.
- Thermal constraints can sometimes be mitigated with network reinforcement eg overhead line restringing
- Thermal constraints can sometimes be mitigated with export limitation

Voltage Drop or Rise

- Occurs when connecting into a heavily/lightly loaded circuit or for connections with a long cable route.
- POCs that exceed acceptable levels will be discounted

Voltage Step Change

- Distribution Code / P28 highlight acceptable limits.
- If a proposed connection causes a voltage step change outside these limits, the POC will be discounted



In addition to Distribution level constraints, Transmission constraints must also be considered.

Appendix G

All 20 GSP sites within the ENWL area are now using the Appendix G process.

This process aims to improve the Statement of Works process and provide greater clarity.

Materiality Headroom

We have assigned 3 materiality statuses to determine the materiality headroom for each GSP.

A – Latest return indicates spare capacity at this location

GSPs with 'A' Status

- Bredbury
- Carrington
- Macclesfield
- Padiham
- Penwortham
- South Manchester
- Washway Farm

B – Insufficient capacity to accommodate further connections without a Modification Application

GSPs with 'B' Status

- Bold
- Kearsley
- Kirkby
- Rochdale
- Stalybridge
- Stannah
- Whitegate

C – Insufficient capacity to accommodate further connections without completing identified transmission work

GSPs with 'C' Status

- Harker – replacement of 4 SGTs and 132kV switchboard
- Hutton - replacement of 4 SGTs and 132kV switchboard
- Heysham – HOPS scheme (to be confirmed)



Carlisle BSP

- Highly limited capability for synchronous generation due to fault level constraints
- Fed from Harker GSP which requires significant NGET works in order to connect

Hazel Grove

- Sufficient headroom for a 33kV 30MW connection of Synchronous, Inverter Connected or Battery Storage Generation
- Fed from Bredbury GSP which currently has a Materiality Status of 'A' – Sufficient headroom without a Modification Application

Lancaster BSP

- Headroom for asynchronous, synchronous and battery storage generation
 - Fed from Heysham GSP, which has 'C' status and requires significant NGET works prior to the energisation of any new connection.

Carrington BSP

- No availability for Synchronous, Inverter Connected or Battery Storage Generation
 - Fed from Carrington GSP, which currently has sufficient headroom to connect.



As shown on the previous slides, there are a number of factors which can influence the viability of a new DG connection. We actively encourage you to engage with us pre-application in order to help you understand potential difficulties for proposed projects. This can be achieved through:

Get in Touch

- Operate an 'open door' policy
- Regularly offer surgery sessions – no need to wait for a DG event

Heat Map

- If you would prefer to assess the network yourself, you can use our Heat Map Tool

Other Information

- Additional information is available on our website



Interactivity Process

Brian Hoy

Stay connected...



www.enwl.co.uk




- As part of Open Networks 2018 DNOs consulted on interactivity
 - Clear feedback from stakeholder on desire for consistency
 - But no clarity on which approach was preferred
- Work carried forward into Open Networks 2019
 - Three options considered:
 - Moratorium
 - Conditional approach (based on UKPN)
 - 'Cumulative' approach
- ENA Open Networks published a joint consultation on Application Interactivity and Queue Management
 - was open for eight weeks and closed on 25 September 2019.
- Consultation was on a 'minded to' consistent approach to interactivity based on the current UKPN approach
- Good level of response:
 - 19 responses received from a broad range of stakeholders
- ENA webinar held 10 Feb and DER Connections Steering Group briefed 20 Feb



- When Interactivity is triggered the applications are ‘queued’
- The application that is first in the Interactive Queue has first refusal on the connection – they are considered ‘*Unconditional*’
- Later applications depend on some or all earlier applications **not** being accepted - they are ‘*Conditional*’
- Applicants will be given early warning that they are Interactive
- Connection Offers are issued in normal timescales and will be issued as Conditional or Unconditional as appropriate
- There is no moratorium period – Interactive Offers are issued with 30 days validity period
- Conditional connection offers don’t have to pay until their acceptance has been confirmed

The 'Conditional' approach for interactivity





Application Interactivity

- Hold stakeholder briefings ~ Feb 2020
- Publish final guide ~ March 2020
- Develop an implementation timetable for network companies to roll out the new process ~ March 2020
- Prepare a process to apply the ‘conditional’ interactivity approach to connections across Transmission and Distribution where there is interactivity between customers connecting to different networks ~ 2020 work
- Extent across Distribution to Distribution and IDNOs to follow in 2020



Network Information

Stay connected...



www.enwl.co.uk



Getting Connected

What We Offer

Network Constraints

- Distribution Constraints
- Transmission Constraints

Pre Application Contact

Interactivity

Network Information

Heat Map Tool

Other Potential Information
Sources

GIS Update

Transition to DSO and Flexibility

DSO Transition

Flexible Services

Flexible Connections



Heat Map Update

Gill Williamson


Stay connected...



www.enwl.co.uk



We have added a map to provide a quick view, supplementing heat map tool workbook



Download here: <https://www.enwl.co.uk/get-connected/network-information/heatmap-tool/>

Heat Map Update



Embedded within the heat map webpage

Based on Google maps – familiar zoom and pan

GSP, BSP and Primary substation locations


Click substation symbols for tabulated data



Our heatmap tool

At Electricity North West we are committed to improving the experience of our customers. As part of this commitment we have developed our heatmap tool. This tool enables developers to assess the level of capacity that might be available for new connections to our network. Our heatmap tool takes the form of an excel work book and contains capacity information on all of our primary substations and bulk supply points. It provides an interface that enables the easy identification of network constraints in the vicinity of your site. The tool is available from the downloads section at the end of this page. In order to improve the user experience we now also provide an interactive map interface that can be accessed below.

We envisage that the tool will be used to inform initial discussion between ourselves and our customers. Although we have taken steps to ensure the accuracy of the heatmap tool, it cannot replicate the level of accuracy provided by the detailed assessment carried out as part of the formal application process. As such, we advise that customers enter into dialog with us before submitting a formal application. Similarly, if the heatmap tool indicates that there is insufficient capacity to accommodate your development please contact us to discuss the next steps. We will always work with customers to find solutions to network constraints, including the deployment of smart technology.



Disclaimer

The information contained in the Heatmap Tool is provided for the sole purpose of allowing existing and potential customers to assess the capabilities of the electricity network and opportunities for changes in their use of the network or for connecting to it.

While all reasonable effort has been made to ensure the accuracy of the information, Electricity North West Ltd will accept not liability for any loss of range caused by the information not being accurate. Actual changes in supply capacity for existing customers or new connections are subject to detailed assessment and approval by Electricity North West Ltd and by the payment of appropriate charges.

The information contained within the Heatmap Tool is the Copyright of Electricity North West Ltd. All Rights Reserved.




Downloads


XLSX Heatmap Tool
(574.0 KB - 2nd Feb 2020)

PDF Heatmap Tool - User Guide
(574.2 KB - 28th Jan 2020)

Heat Map Update



-  Grid Supply Point substation
-  Bulk Supply Point substation
-  Primary substation






Click to the substation shape to display tabulated data

 Primary data:-

- Upstream feeding arrangement
- Appendix G info
- Firm and non-firm demand headroom
- Generation headroom
inverter, LV synchronous,
HV synchronous and battery
types






Click to the substation shape to display tabulated data



GSP data:-

- Appendix G info
- Appendix G parameters
- Part 1 existing gen cap
- Part 2 existing gen with specific requirements
- Part 3 existing gen interim requirements
- Part 4 contracted to connect pending transmission works
- Part 5 materiality headroom
- Transmission fault level headroom
- Status





New way to access our network capacity data

Retain heat
map tool
workbook

Same
information
just different
ways of
visualising

Same
monthly
refresh rate

- Does not replace detailed assessments
- Indication of constraints doesn't mean that we can't connect you

Heat map Update



- Click on the Substation in Excel to take you to the map location



11 kV & 6.6 kV Connections

The results given by this tool are based on high level approximations only. It should also be noted that the network may have changed since the last time the data was updated. As such, the outcome of a formal application may differ from the results given by this tool. For further information on how to interpret the data contained within this workbook please refer to the user guide embedded within the first tab.

Please note that the value of headroom quoted by this tool is based on total capacity available for new connections not the maximum size of a single connection which can be much lower. It is normally not possible to accommodate a single connection of more than 7 MW at 11kV or 6.6 kV. This is based on the typical load rating of items of plant such as circuit breakers, current transformers and cable terminations.

Inputs				Key	
Easting	356710	Use the controls to the left to find the nearest primary substations to your site. The results will be displayed in the table below. When the desired site capacity and connection type are entered an estimate of available headroom and connection feasibility will be displayed. The results are based on both local constraints and constraints at the associated BSP.		Capacity < 90% of headroom	
Northing	431558			Capacity > 90% & < 100% of headroom	
Capacity (MW)	5			Capacity > 100% of headroom	
Connection Type	Demand - Firm				

Distribution Network Capacity								Transmission Constraints (App G)		
No	Distance (km)	Primary Substation	BSP Group	BCA Group (GSP)	Primary Substation Locat	Headroom (MW)	Can Connect?	Materiality Headroom	Fault Level Headroom	Transmission System Comment (see G)
1	0.06	RIBBLETON	PRESTON EAST	PENWORTHAM	356730	431506	10.6	-	-	-
2	1.37	PRESTON EAST	PRESTON EAST	PENWORTHAM	356777	432926	10.6	-	-	-
3	1.91	DODGSON RD	PRESTON EAST	PENWORTHAM	355190	430397	10.6	-	-	-
4	2.62	ST MARY'S ST	BIBBLE	PENWORTHAM	354932	429640	6.5	-	-	-
5	3.25	BUSHILL ST	BIBBLE	PENWORTHAM	353809	430094	4.8	-	-	-
6	3.32	CRAGGS ROW	BIBBLE	PENWORTHAM	353740	430080	3.1	-	-	-
7	3.58	AVENHAM	PRESTON EAST	PENWORTHAM	354028	429192	4.2	-	-	-
8	3.94	BLACKBULL	BIBBLE	PENWORTHAM	353041	433005	7.1	-	-	-
9	4.35	JULKETH	BIBBLE	PENWORTHAM	352393	431036	7.5	-	-	-
10	4.48	HIGHER WALTON	LEYLAND	PENWORTHAM	358020	427270	0.0	-	-	-

← Ribbleton (33 kV / 6.6 kV) ↗

Name

Ribbleton (33 kV / 6.6 kV)

Easting

356730

Northing

431506

BSP Group

Preston East

BCA Group (GSP)

Penwortham

Appendix G Summary (See GSP for More Details)

Transmission Headroom Available

Firm Demand Headroom (MW)

10.6

Non Firm Demand Headroom (MW)

10.6

Inverter Based Generation Headroom (MW)

11.2

LV Synchronous Generation Headroom (MW)

2



Other Potential Information Sources

Gill Williamson

Stay connected...



www.enwl.co.uk




LTDS

Long term Development Statement

Comprises:

- Report
- Schematic diagrams
- Network data workbook



Network data:

- Circuit data
- Transformer data
- Load information forecast to 2023/24
- Fault Level information
- Generation information
- Development proposals


<https://www.enwl.co.uk/get-connected/network-information/long-term-development-statement/>

DFES

Distribution Future Electricity Scenarios

Comprises:

- DFES Report explaining scenarios
- Forecasts data workbook
- Regional Insights analysis report



Forecasts to 2050 x 5 scenarios broken down per substation:

- Number of EVs and number of HPs
- Maximum and minimum demand
- Generation capacity per technology
- Reactive power
- Energy

<https://www.enwl.co.uk/get-connected/network-information/dfes/>



System Wide Resource Register SWRR

Comprises:

- Resource workbook

Industry agreed format

Updated monthly

Some data is redacted to protect the identity of specific resources

System wide resource register

Download Electricity North West's system wide resource register for an overview of the Distributed Energy Resource connections to our network above 1MW, along with contracted flexibility.

Resource data:

- Generators, storage >1MW
- Already connected or accepted to connect, distribution and transmission service provided
- Flexibility services

<https://www.enwl.co.uk/get-connected/network-information/system-wide-resource-register/>



Geographical Information System (GIS) Update

Hannah Sharratt

Stay connected...




www.enwl.co.uk

Proposed Offering



- Web based application
- Better access arrangements – 24/7
- Update period more frequent – improved time delay from site data appearing in GIS system
- Simple Browser or Download for your own GIS software
- More information displayed on asset attributes

Timeline




Proposed Views



- Proposed home view

- Better definition of assets
- More detailed asset information
- Interactive map



Proposed Views



- Improved cable asset data

The screenshot shows the Electricity North West GIS Viewer interface. The map displays a cable route near 'El Sub Sta' and 'Copes'. A red arrow points from the 'Improved cable asset data' bullet point to the 'Info' tab in the right-hand panel. The 'Info' tab displays the following data:

Depth	
Drum Number	
Feat Code	hv_cable
Feat Num	215063739
Associated Conductor	Not Applicable
Id Cable Class	2
Cable Class	HV Underground
Cable Size	0.30in2
Criticality	
Comm Driver	
Decomm Driver	
Id Installation Medium	8
Installation Medium	Laid Direct
Installation Type	Not Applicable
Installer Name	
Insulation	Not Applicable
Manufacturer	
Mixed Wire Size	No
No Core Wires	3
Ownership	Electricity North West Ltd
Phases Connected	Three Phase

- Improved plant asset data

The screenshot shows the Electricity North West GIS Viewer interface. The map displays a plant asset with various labels like '12345', '165593', and '4C .25'. A red arrow points from the 'Improved plant asset data' bullet point to the 'Info' tab in the right-hand panel. The 'Info' tab displays the following data:

Orientation	285.205
Date Creation	2001-01-01 00:00:00.0
State	Existing
Id Transformer Type	5
Transformer Type	Ground Mounted (3ph)
Circuit Monitoring Id	0
Feat Num	215054984
Fid Primary Connection	
Fid Polestructure	
Fid Substation	20485917
Higher Voltage Colour	#0000FF
Criticality	
Indoors	Indoor
Infeed Voltage	6.6kV
Outfeed Voltage	415V
Ownership	Electricity North West Ltd
Rating Normal	500 kVA
Variable Rating	Not Applicable
Last Update Date	2019-05-23 18:34:28.0
Last Update User	CR065



Transition to DSO and Flexibility

Stay connected...



www.enwl.co.uk



Getting Connected

What We Offer

Network Constraints

- Distribution Constraints
- Transmission Constraints

Pre Application Contact

Interactivity

Network Information

Heat Map Tool

Other Potential Information Sources

GIS Update

Transition to DSO and Flexibility

DSO Transition

Flexible Services

Flexible Connections



DSO Transition

Steffan Jones

Stay connected...




www.enwl.co.uk

Increasing network complexity




Historically controlling single directional flows

- 18 connections to National Grid transmission network.
- 6 connections to other DNOs



As a DSO controlling bi-directional flows

- 18 connections to National Grid transmission network.
- 6 connections to other DNOs
- Hundreds of connections to IDNOs
- Tens of thousands of customer connections





- A large quantity of the ICE and business change program plans for 2018 & 2019 have been associated with the transition to enhancement of Distribution System Operation functionality within ENWL.
- Distribution System Operation can be segregated into a range of functions, some are inherently the responsibility of the DNO to deliver, however many are already widely open to competition and market participation.
- Some of the DSO functions were already part of the role of a DNO and will be enhanced, whilst some are completely new.
- We believe that DNOs should retain responsibility for all DSO functions which preserve the system security and are directly linked to the licence obligation of:
“Permit the development, maintenance, and operation of an efficient, co-ordinated, and economical system for the distribution of electricity;” (licence condition 21)

Benefits of DSO transition



Improved customer experience

- Improved customer experience through sharing of best practice within the ENA Open Networks project



Efficiency savings

- Increase utilisation of networks assets allowing for efficiency savings



Whole system investment

- Improved whole system investment decisions through closer working relationships with other network providers



Low carbon economy

- Facilitating the transition to a low carbon economy.



Increased flexibility

- Allowing all customers the ability, independent of size, to participate in energy trading and balancing



Increased productivity


- Increased productivity as a result of developing new modelling tools, implementing new systems, and improved automation

What have we done to date



Distribution Future Electricity Scenarios Documents

- 2 years of DFES publications
- 2019 FES includes data workbook
<https://www.enwl.co.uk/get-connected/network-information/dfes/>



Requests of Flexible Services

- 14 Requirements published
- 5 Tenders undertaken
- 52MW asked for
<https://www.enwl.co.uk/get-connected/network-information/flexible-services/>




What have we done to date



Heat Mapping Tool

- In 2018 we published the new improved heat mapping tool.
- Tool is updated monthly
- Enables developers to assess the level of capacity that might be available for new connections to our network.

<https://www.enwl.co.uk/get-connected/network-information/heatmap-tool/>



Bringing energy to your door

11 kV & 6.6 kV Connections

The results given by this tool are based on high level approximations only. It should also be noted that the network may have changed since the last time the data was updated. As such, the outcome of a formal application may differ from the results given by this tool. For further information on how to interpret the data contained within this workbook please refer to the user guide embedded within the first tab.

Inputs	
Easting	Enter Data
Northing	Enter Data
Scheme Capacity (MW)	Enter Data
Connection Type	Enter Data

Use the controls to the left to find the nearest primary substations to your site. The results will be displayed in the table below. When the desired site capacity and connection type are entered an estimate of available headroom and connection feasibility will be displayed. The results are based on both local constraints and constraints at the associated BSP.

Results								
No	Distance (km)	Primary Substation	BSP Group	GSP Group	Primary Substation Location		Headroom (MW)	Can be accommodated? (RAG)
					Easting	Northing		
1	-	-	-	-	-	-		
2	-	-	-	-	-	-		
3	-	-	-	-	-	-		
4	-	-	-	-	-	-		
5	-	-	-	-	-	-		
6	-	-	-	-	-	-		
7	-	-	-	-	-	-		
8	-	-	-	-	-	-		
9	-	-	-	-	-	-		
10	-	-	-	-	-	-		

Connection Types	
Demand Firm	The connection of load which is secure for a first circuit outage.
Demand N-0	The connection of load which can be actively constrained off under outage conditions.
Generation Synchronous (LV)	Generation such as diesel or gas turbines connected to the LV network through step up transformers.
Generation Synchronous (HV)	Generation such as diesel or gas turbines connected to the HV network directly i.e. without step up transformers.
Generation Inverter Based	Generation technologies connected by inverters this typically includes solar and wind generators.
Battery Energy Storage	Inverter connected battery energy storage schemes.


Key: RAG rating is based on scheme capacity as percentage of available headroom.

Green	Capacity <90% of headroom
Yellow	Capacity >90% & <100% of headroom
Red	Capacity >100% of headroom

Carbon Plan

- Publication of the carbon plan in 2019
- Maps out how we intend to reduce emissions 10% year on year.

<https://www.enwl.co.uk/zero-carbon/leading-the-north-west-to-zero-carbon/>




What have we done to date



Open Networks Project

- Worked collaboratively with the other industry members to develop shared processes, identify best practices, and enhance whole system development.
- Consultations on: impact assessment, connection queues, interactivity, and flexible services.


<http://www.energynetworks.org/electricity/futures/open-networks-project/>



Flexible Connections


- We offer constrained or flexible connection offers as standard, which means you could benefit from avoiding reinforcement costs and associated timescales for traditional network reinforcement.

<https://www.enwl.co.uk/get-connected/apply-for-a-new-connection/managed-connections/>





- Publication of System Wide Resource Register
- Changes to the interactivity process
- Changes to the queue management process
- Alignment of flexible services contracts with other DNOs
- Publication of Digitisation strategy





Flexible Services

Steffan Jones

Stay connected...



www.enwl.co.uk




On 28 March we published 4 new requirements for flexibility

The tender opens for submissions on 17 April 2020

The tender closes to submissions on 18 May 2020



You can register your interest to participate in this tender on our webpage



For more information on the requirements for this tender please visit
www.enwl.co.uk/flexible-services/current-request-for-proposals

Recent improvements following feedback



We have now published the full half hourly requirements for our current requirements



You can now register your asset via an online form, and we will contact you directly when there is a requirement in your area



We are the first DNO to adopt the industry agreed consistent branding for flexible service products
(Sustain, Secure, Dynamic, Restore)



Flexible Connections

Steffan Jones

Stay connected...



www.enwl.co.uk



Export limiting devices

Flexible Connection Solution where automated equipment at the User's site/substation ensures that the User's Agreed Export Capacity is not exceeded.

Available to all generation customers where export capacity is deemed to be an issue or where the site does not wish to export/limited export requirements. Sites should adhere to EREC G100 standards.

Remote Constraint Connection

Flexible Connection Solution where capacity is temporarily reduced (which may be zero) for system abnormal network conditions. These may be distant from the customer's site and are monitored in real-time.

Currently ENWL offers remote constrained connections to all generation sites $\geq 200\text{kVA}$ in the form of rapid and controlled shutdown procedures.

Intertripped connections

Flexible Connection Solution which will disconnect some/all of the site for a prescribed system abnormal network condition, such as another circuit breaker opening.

Applied within ENWL where a network critical disconnection is required following an abnormal running condition within protection timescales ($<1\text{s}$).

It is not always possible to technically or financially facilitate a flexible connection to all sites. Your designer will be able to advise on a site by site basis.



We are developing:

Timed Capacity Connections - a Flexible Connection Solution where the User manages their import/export level within a prescribed operating schedule agreed within their Connection Agreement.

Active Network Management - a Flexible Connection Solution where distributed control systems continually monitor network parameters and allocate capacity to customers in order that performance remains within limits.

Import Limited Connections - a Flexible Connection Solution where automated equipment at the User's site/substation ensures that the User's Agreed Import Capacity is not exceeded.

Where possible, ENWL has taken the opportunity to trial these technologies. Although these are not currently business as usual, we are happy to discuss the potential for these solutions on a trial basis.

Lunch & Networking





Incentive on Connections Engagement (ICE) 2019-20 Update

Hannah Sharratt

Stay connected...



www.enwl.co.uk

ICE 2019-20 Workplan Performance



Action	Progress
➤ Communicate with our Stakeholders on Engineering Recommendation G99 requirements for the connection of Generation Equipment.	✓ Presented at 3 workshops and 2 webinars
➤ Engage with Stakeholders on our transition to Distribution System Operator (DSO) Strategy.	✓ Presented at DG HV/EHV workshop and Owner Operator Forum
➤ Continuously improve how we provide information and publish requirements for flexible services , such as Demand Side Response.	✓ Consultation completed. ✓ 3 workshop presentations provided. ✓ New information & guidance published
➤ Clearly communicate where flexible connection options are available.	✓ Presentation at workshop ✓ Options discussed during quoting process, where applicable
➤ Provide briefings for stakeholders on the proposed changes to charges through Ofgem's significant code review .	✓ Presentation at workshop and 2 webinars.
➤ Review our interactivity processes in line with best practise identified through the Open Networks Project.	✓ Ongoing in line with national timelines, roll out planned for next year ✓ Presented at workshops.
➤ Lead the national engagement with stakeholders on more consistent DNO connection charging approach to make charging fair for all of our customers.	✓ Update provided at workshop. No changes to current approach planned.

ICE 2019-20 Workplan Performance



Action	Progress
➤ Engage with our Stakeholders to improve outage communications , adopting the principles of the Solar Trade Association (STA) best practice guide and apply where appropriate.	<ul style="list-style-type: none"> ✓ Best practise implemented in line with STA Guidance ✓ Presented at Owner Operator Forum
➤ Improve access and presentation of information on available thermal capacity and fault level on our network.	<ul style="list-style-type: none"> ✓ Enhanced Heatmap Tool now available with improved geographical view
➤ Engage with stakeholders to review and improve the post acceptance process .	<ul style="list-style-type: none"> ✓ On track
➤ Engage with our stakeholders on the impact of our new Network Management System .	<ul style="list-style-type: none"> ✓ Impact of new Network Management System reviewed – no impact for DG HV/EHV customers
➤ Target improved Time to Quote timescales (57 working days).	<ul style="list-style-type: none"> ✓ On track: HV 36 days; EHV 52 days
➤ Improve 3 rd party access to our Network Information on GIS.	<ul style="list-style-type: none"> ✓ New functionality available for stakeholder testing in March, with planned roll out from April.
➤ Improve communications on Transmission Constraints .	<ul style="list-style-type: none"> ✓ On track
➤ Engage with Stakeholders to improve the ENWL ' Get Connected ' website.	<ul style="list-style-type: none"> ✓ Website improvements implemented. Collating feedback via webinars and surveys.



- Business As Usual commitments

➤ We will continue to offer opportunities for stakeholders to engage with us.

- ✓ 2 workshops held in area
- ✓ 1 London workshop
- ✓ 9 Surgery session opportunities, now also offering request a surgery sessions
- ✓ Multiple webinars available, including Ofgem Charging Review, G99 & G98

➤ We will continue to communicate with our stakeholders by issuing regular updates on ICE Commitments, Policy and Health & Safety updates to registered stakeholders

- ✓ Quarterly updates and newsletters published for ICE
- ✓ All updates available on our website



Talk to the experts

In addition to the Connections surgery appointments we run throughout the year, you can request a meeting at an alternative time that is convenient for you.

[Request a meeting](#) →

ICE Workplans are available [here](#)





Ofgem Significant Code Review

Brian Hoy

Stay connected...



www.enwl.co.uk

What is the Access SCR?



- **A Significant Code Review (SCR)** allows Ofgem to initiate wide ranging and holistic change and to implement reform of a code based issue.
- **Objective of Access Significant Code Review (SCR):** to ensure electricity networks are used efficiently and flexibly, reflecting users' needs and allowing consumers to benefit from new technologies and services while avoiding unnecessary costs on energy bills in general.
 - **Access arrangements** - the nature of users' access to the electricity networks (for example, when users can import/export electricity and how much) and how these rights are allocated:
 - **Forward-looking charges** –the type of ongoing electricity network charges which signal to users how their actions can either increase or decrease network costs in the future
- **Scope:**
 - Review of the definition and choice of transmission and distribution access rights
 - Wide-ranging review of Distribution Use of System (DUoS) network charges
 - **Review of distribution connection charging boundary**
 - Focussed review of Transmission Network Use of System (TNUoS) charges



- Ofgem's focus this year is on developing and assessing a long-list of options. They are sharing their thinking through two working papers:
 - 1st working paper – published September 2019
 - An initial overview and assessment of options for access rights, better locational DUoS signals and charge design.
 - The links between access, charging and procurement of flexibility.
 - 2nd working paper – published December 2019
 - **Distribution connection charging**
 - Small user treatment
 - Focused transmission charging reforms
- A shortlist of options will be assessed in further detail this year, with consultation on their draft SCR conclusions in summer 2020
- Further information on the reviews can be found at
 - <http://www.chargingfutures.com/charging-reforms/access-forward-looking-charges/proposed-changes-and-potential-impacts/>
 - <https://www.ofgem.gov.uk/electricity/transmission-networks/charging/reform-network-access-and-forward-looking-charges>

Ofgem's Access and Forward Looking Charging SCR


2nd Working Paper December 2019



What is the 'connections boundary'?



When connecting to the network there can be different kinds of assets required to make the connection. The 'connections boundary' describes the assets that the customer has to pay for.



How does it work now and what are the issues?



Transmission

- **Shallow connection boundary**
- Pay for new connecting assets up front or over time
- TOs must fund any necessary reinforcement via RIIO allowances or the ESO could actively manage the constraints through flex markets
- To protect against TOs undertaking reinforcement that is not then used, users provide securities against them cancelling their projects ('user commitment')

Distribution

- **Shallow-ish connection boundary**
- Pay upfront for new connecting assets and a share of any necessary reinforcement of the upstream network
- Can lead to high connection charges and might reduce incentives for DNOs to invest strategically, **but** provides a locational signal
- Protects wider consumers from the risk of stranded or under used infrastructure



Potential problems with these arrangements

- The difference between arrangements may be distorting investment decisions or competition between projects
- The connection arrangements could be creating barriers to entry for some users (eg upfront cost) and slow down connections of new technologies like distributed generation and EV charging infrastructure

What options are Ofgem considering?



**Shallow-ish connection
boundary**
current arrangements

Shallower
still recovering some
reinforcement costs through
connection charges, but less
than now

Shallow
no longer recovering any
reinforcement costs through
connection charges

Alternative payment arrangements

it might be possible to combine alternative payment terms such as payment over time with any of the other options

What are Ofgem's initial thoughts?



Connection boundary depth	Pros	Cons
<ul style="list-style-type: none">• Shallow-ish (keep the existing boundary but could still implement other approaches such as alternative payment terms)	<ul style="list-style-type: none">+ Delayed payment may reduce issues associated with high upfront cost.	<ul style="list-style-type: none">- Could expose DNOs to bad debt risk.
<ul style="list-style-type: none">• Shallower (still recovering some reinforcement costs through connection charges, but less than now)	<ul style="list-style-type: none">+ Would reduce cost but keep some locational signal depending on where new level is set.+ Recovering more from network charges could mean more opportunity for innovative/ more strategic solutions to network development.	<ul style="list-style-type: none">- Weaker locational signal but could be mitigated by more locational DUoS charging.
<ul style="list-style-type: none">• Shallow (no longer recovering any reinforcement costs through connection charges)	<ul style="list-style-type: none">+ Increased opportunity for DNOs to consider alternative approaches to developing their network+ Lowest level of upfront cost to connecting users	<ul style="list-style-type: none">- Weakest locational signal and could create an incentive to over-request capacity required.- May be excessively complex and/or risk introducing cross-subsidies between users

Significant Code Review Timetable - Key Milestones



- The reviews are likely to result in major changes to the charging and access arrangements for customers
- Aim is to finalise the proposals mod 2021 in time for DNO RIIO-ED2 Business Plan Submissions
- Reviews are still at an early stage and impacts not yet clear
- Further updates will be provided as further information becomes available.



Shaping our 2020-21 ICE Workplan

Hannah Sharratt

Stay connected...



www.enwl.co.uk

Your Priorities ?




- For each of the following topics, please indicate the level of **importance** to you
 - 1 = low importance, 5 = extremely important


Competition in Connections	Training & Guidance	Clarity of Customer Responsibilities
Process	Time To Quote	Communications
Land Rights & Consents	Time To Connect	Pre-application support / Ease of application
Cost	Interactivity	Payment Options
Local Economy	Access to Information	A&D Fees
Flexible Connection Options	Clarity of our Requirements	Other factors, eg Highways, National Rail, BEIS, Local Authorities



How we create the proposed plan...



Draft 2020-21 ICE Workplan



ICE Commitments League – Ranking exercise



- **Individual activity:** Using the sheets provided, please categorise each proposed ICE commitment.
- **Group activity:** Using the cards provided, please categorise each proposed ICE commitment.
- Please also provide feedback on our proposed actions, and describe how this will benefit you.

Club	MP	W	D	L	GF	GA	GD	Pts	Last 5
1 Liverpool	28	26	1	1	64	20	44	79	🔴🟢🟢🟢🟢
2 Man. City	27	18	3	6	68	29	39	57	🟢🟢🔴🟢🟡
3 Leicester City	28	13	6	9	47	39	8	45	🔴🔴🟡🟡🟢
4 Chelsea	28	11	9	8	42	30	12	42	🟡🟢🟢🟡🔴
5 Man United	28	10	12	6	41	34	7	42	🟢🟢🟡🟡🔴
6 Wolves	28	11	7	10	46	39	7	40	🔴🔴🟢🟢🟢
7 Tottenham	27	10	10	7	29	25	4	40	🟡🟢🟢🔴🟡
8 Sheff Utd	28	11	5	12	33	39	-6	38	🟡🟢🟢🟡🟢
9 Burnley FC	27	8	13	6	39	36	3	37	🟢🟢🟡🟡🟡
10 Arsenal	27	8	9	10	25	32	-7	36	🟢🟢🔴🔴🔴
11 Everton	28	10	4	14	35	51	-16	34	🔴🟢🔴🔴🟢
12 Crystal Palace	28	8	8	12	24	41	-17	32	🟡🔴🔴🟡🟡
13 Southampton	28	6	10	12	32	40	-8	28	🔴🟡🟡🟡🔴
14 Newcastle	28	7	6	15	35	49	-14	27	🟢🔴🔴🟡🔴
15 Brighton	28	6	9	13	27	43	-16	27	🟢🔴🟡🔴🔴
16 West Ham	28	7	6	15	28	45	-17	27	🟡🔴🔴🟢🟢
17 Watford	28	5	6	17	25	51	-26	21	🟢🔴🔴🟡🔴
18 Bournemouth	28	5	6	17	25	51	-26	21	🟢🔴🔴🟡🔴
19 Aston Villa	28	5	6	17	25	51	-26	21	🟢🔴🔴🟡🔴
20 Norwich City	28	5	6	17	25	51	-26	21	🟢🔴🔴🟡🔴

Into Europe

Mid Table

Relegation Zone



Thank you

Coffee Break





G99 Update

Gill Williamson

Stay connected...



www.enwl.co.uk



Recap on G99
fundamentals

Type A
update

ENA Type
Test Register

Type B
update

PGMD
process

Reactive
power
capability
evidence

Type C
update

Frequency
testing

Monitoring

Models

Resources

Recap on G99 fundamentals





- Generators have a legal requirement to comply with G99
- Manufacturers should assist with some of the necessary compliance information
 - Type Test
 - Manufacturer's Information
 - Test reports
- Electricity North West have a legal requirement to assure compliance



G98 & G99 are evolving, so please always check for and use the latest versions.

Latest versions from 9th March 2020 are:


G98 Issue 1 Amendment 4

G99 Issue 1 Amendment 6

<https://www.energynetworks.org/electricity/engineering/distributed-generation/engineering-recommendation-g99.html>



- Types affect technical requirements and which forms you use







Types depend
on
PGM capacity

PGM
definition
depends on
whether the
technology is
synchronous /
asynchronous

SYNCHRONOUS SCHEME



ASYNCHRONOUS SCHEME



86


Generating Unit, GU

Power Generating Module, PGM

Power Generating Facility, PGF




3 x 4MW Type B Synchronous PGMs = 12 MW PGF





1 x 4 MW Inverter connected plus 2 x 4 MW Asynchronous GU =
12 MW Type C PPM = 12 MW PGF



Power Generating Module
(PGM) / Power Park Module
(PPM)

Power Generating Facility
(PGF)

Type A Update





Summary of G98 and G99 Forms

	Single premises Up to and including 16 A per phase	Multiple premises Up to and including 16 A per phase	Less than 50kW	Integrated Micro-generation & storage (each up to & including 16 A per phase)	Greater than 50kW & less than 1MW Type A	1MW to less than 10MW Type B	10MW to less than 50MW Type C	Greater than or equal to 50MW or >110kV Type D
Applicable Standard	G98	G98	G99	G99	G99	G99	G99	
Application		Form A	Form A1-1	Form A1-2	SAF*	SAF*	SAF*	
Notification	Form B	Form B	Form A3-1	Form A3-2	Form A3-1			
Evidence	If fully type tested but not registered with the ENA- Form C	If fully type tested but not registered with the ENA- Form C	If not type tested – Form A2-1 synchronous <50kW, Form A2-2 synchronous >50kW or Form A2-3 inverter connected gen	If not type tested – Form A2-1 synchronous <50kW, Form A2-2 synchronous >50kW or Form A2-3 inverter connected gen	If not type tested- Form A2-2 synchronous Form A2-3 inverter connected gen	PGMD** Form B2-1	PGMD** Form C2-1	
Site Compliance and Commissioning Checks					Form A2-4 if the Interface Protection is not Type Tested or for other site compliance tests	Form B2-2 if the Interface Protection is not Type Tested or for other site compliance tests	Form C2-2 if the Interface Protection is not Type Tested or for other site compliance tests	
Installation						Form B3	Form C3	

Consult our G99 summary sheet to quickly determine which form you need

G99 summary

<https://www.enwl.co.uk/globalassets/get-connected/new-connections/generation/g99/g99-summary-guide.pdf>

G98 summary

<https://www.enwl.co.uk/globalassets/get-connected/new-connections/generation/micro-generation/g98-summary-guide.pdf>



ENA Type Test Register is available @ <http://www.ena-eng.org/gen-ttr/>

Product manufacturers upload data and documentation relating to their products

Manufacturers have been requested to resolve issues with most of the 370 entries

Manufacturers are requested to provide missing or incorrect information

The screenshot shows the 'Type Test Register' website. The header includes a 'Home' link. The main content area is divided into two columns. The left column, titled 'Find/Browse Devices', contains search filters: 'Search Model or Reference' (with a search icon), 'Manufacturer' (with a dropdown menu), 'Device Category' (with a dropdown menu), 'Device Type' (with a dropdown menu), 'Published between' (with two date pickers), 'and' (with a dropdown menu), 'Registered capacity between' (with two input fields for Min and Max in kW), and a 'Search/Filter' button with a 'Reset' button. The right column, titled 'Introduction' and 'Latest Devices', contains an 'Introduction' section. The introduction text states: 'The Energy Networks Association (ENA) represents the interests of all en G98 and G99 are ENA standards that outline the requirements for conn these standards are available free from the [ENA Document Catalogue](#). This site enables logged in manufacturer users to enter details and uplo The Energy Networks Association (ENA) has developed and hosts the sit relating to their products. The ENA simply hosts manufacturers' data a The majority of data and documents on the site are available to all users Operator (DNO) users or users from the manufacturer of the device. DNO or manufacturer users can log in by clicking [here](#). Unregistered DN used. For more information, please direct your query to: Energy Networks Association Ltd 4 More London Riverside London, SE1 2AU Contact: Lauren Fisher Tel: +44 (0)20 7706 5100 Email: lauren.fisher@energynetworks.org If you have any problems or issues with the site or have any comments'.

EREC G99 Update – Type A



Manufacturer's Reference Number is obtained from the ENA Type Test Register website
www.ena-eng.org/gen-ttr

Type Test Register

Home

Guest

User Guide

Contact Us

ena

energy networks association

Find/Browse Devices

Introduction

Latest Devices

Search Results

Search Model or Reference

Q

Step 1

Manufacturer

☒ Solis (Ginlong) (previously Ningbo Ginlong)

Device Category

☒ Inverter

Device Type

Select one or more ...

Published between

Month/Year

and

Month/Year

Registered capacity between

2.9

and

3.1

Step 2

Q Search/Filter

Reset

27 Devices Found

Download

System Reference	Published	Manufacturer	Model	Category	Type	Registered Capacity	No. of Phases
SOLIS/D1480/V1	11 Oct 2019	Solis (Ginlong) (previously Ningbo Ginlong)	Solis-mini-3000-4G	Inverter	PV	3 kW	One
SOLIS/D1464/V1	11 Oct 2019	Solis (Ginlong) (previously Ningbo Ginlong)	Solis-mini-3000-4G	Inverter	PV	3 kW	One
SOLIS/D1448/V1	11 Oct 2019	Solis (Ginlong) (previously Ningbo Ginlong)	Solis-1P3K-4G	Inverter	PV	3	
SOLIS/D1449/V1	11 Oct 2019	Solis (Ginlong) (previously Ningbo Ginlong)	RHI-3K-48ES-NI	Inverter	PV	3	
SOLIS/D1437/V1	11 Oct 2019	Solis (Ginlong) (previously Ningbo Ginlong)	Solis-1P3K-4G	Inverter	PV	3	
SOLIS/D1433/V1	11 Oct 2019	Solis (Ginlong) (previously Ningbo Ginlong)	RAI-3K-48ES-5G	Inverter	PV	3	
SOLIS/D1432/V1	11 Oct 2019	Solis (Ginlong) (previously Ningbo Ginlong)	RHI-3K-48ES	Inverter	PV	3	
SOLIS/D1421/V1	10 Oct 2019	Solis (Ginlong) (previously Ningbo Ginlong)	Solis-mini-3000-4G	Inverter	PV	3	
SOLIS/D1404/V1	10 Oct 2019	Solis (Ginlong) (previously Ningbo Ginlong)	Solis-1P3K-4G	Inverter	PV	3	
SOLIS/D1399/V1	10 Oct 2019	Solis (Ginlong) (previously Ningbo Ginlong)	RHI-3K-48ES	Inverter	PV	3	
SOLIS/D1379/V1	9 Oct 2019	Solis (Ginlong) (previously Ningbo Ginlong)	Solis-mini-3000-4G	Inverter	PV	3	
SOLIS/D1368/V1	9 Oct 2019	Solis (Ginlong) (previously Ningbo Ginlong)	Solis-1P3K-4G	Inverter	PV	3	
SOLIS/D1365/V1	9 Oct 2019	Solis (Ginlong) (previously Ningbo Ginlong)	RAI-3K-48ES-5G	Inverter	PV	3	
SOLIS/D1364/V1	9 Oct 2019	Solis (Ginlong) (previously Ningbo Ginlong)	RHI-3K-48ES	Inverter	PV	3	
SOLIS/D0807/V1/A1	3 Sep 2019	Solis (Ginlong) (previously Ningbo Ginlong)	Solis-mini-3000-4G	Inverter	PV	3	
SOLIS/D0800/V2	3 Sep 2019	Solis (Ginlong) (previously Ningbo Ginlong)	Solis-1P3K-4G	Inverter	PV	3	
SOLIS/D0786/V1/A1	26 Aug 2019	Solis (Ginlong) (previously Ningbo Ginlong)	RHI-3K-48ES	Inverter	PV	3	
SOLIS/D0783/V1/A1	26 Aug 2019	Solis (Ginlong) (previously Ningbo Ginlong)	Solis-mini-3000-4G	Inverter	PV	3	
SOLIS/D0771/V1/A1	26 Aug 2019	Solis (Ginlong) (previously Ningbo Ginlong)	Solis-1P3K-4G	Inverter	PV	3 kW	One

Step 1

Select manufacturer, device category and an appropriate registered capacity range

Step 2

Click the Search/Filter button

Step 3

Identify the micro generator model using this column

Step 4


The System Reference of the micro generator to be entered on the Form B

We have a guidance sheet available for completing G98 installation form and it may also be useful for applications for G99 type tested generators

<https://www.enwl.co.uk/get-connected/apply-for-a-new-connection/generation-connection/>

Type B update





PGMD must be submitted at least 28 days prior to synchronisation




Please use the word version of the PGMD clearly signpost evidence using filenames, report section, figure and table numbers

Experience is that everybody (DNOs, Generators and manufacturers) is still learning, so please consider your requirements early

Generators are free to choose method of compliance

Check detailed technical requirements, simple declaration is not acceptable

BESS and short term parallel are exempt from some technical requirements





Temporary network access?

As endorsed by the ENA, Type B and C generators may be able to fully operate after commissioning tests and before the FON is issued if:

- 1) The connection is **safe**, i.e. adequate commissioning completed
- 2) ENWL are satisfied that the connection will **not affect the operation** of our distribution network, i.e. checked protection, flicker and harmonic impact has been confirmed to be compliant with P28 and G5 respectively
- 3) We are satisfied that the Generator is **taking steps to demonstrate compliance**


Operation in advance of the FON will be conditional and time limited
We may consider an ION arrangement

reactive power capability


Continuous operation between 0.95 leading and 0.95 lagging Power Factor

At initial stage (IS) Options = S,MI

According to the PGMD - evidenced by carrying out simulation study in accordance with B.4.2/C.7.3/C.9.3 and by submission of a report



Load flows




Generator Performance Chart / Capability Curve

- *DNOs can accept a generator capability curve as evidence of reactive power capability compliance*

Type C Update






G99 requires Type A, B, C and D PGMs to demonstrate:- **frequency response**
(active power output with falling frequency)

Able of continue to operate during frequency ranges	
At initial stage (IS)	Options = MI, TV
Frequency range	Duration
47 - 47.5 Hz	20s
47.5 – 49 Hz	90 minutes
49 -51 Hz	continuous
51 – 51.5 Hz	90 minutes
51.5 – 52 Hz	15 minutes
Evidence is normally in the form of a table listing time alongside frequency and power output	

Active power shall not drop more than shown in figure 12.1	
At FON stage (FONS) Options = MI, TV, T Synchronous PGMs only	
Frequency range	Active Power output
49.5 Hz for 5 minutes	100%
49 Hz for 5 minutes	Not less than 99%
48 Hz for 5 minutes	Not less than 97%
47.6 Hz for 5 minutes	Not less than 96.2%
47.1 Hz 20 seconds	Not less than 95% without tripping
Evidence is frequently in the form of a graph	



- *Conducting these tests for Type C and D is often impractical due to the size of the load bank*
- *ENA expects some discretion*
- *G99 B5.3 states “tests can be undertaken...”, not “shall”*
- *DNOs have latitude to agree an alternative test approach for larger PGMs*



Annex C.6 requires a Recording Device to be installed for all Type C and Type D generation projects

- Potential issues with minimum measurement requirements and definition of accuracy in Table C.6.1
- Siemens are holding discussions with ENA and National Grid to agree practical revisions
- Not on PGMD (yet)
- *ENA have agreed that DNOs can apply leniency in the meantime*

Table C.6.1 Accuracy and resolution requirements for dynamic system monitoring

Quantity	Measurement Range	Accuracy ±% of nominal	Resolution ±% of nominal	Comment
RMS voltage	0 – 1.5 V _n	0.1	0.01	Crest factor ≤1.5
Voltage phase sequence components	0.8 V _n – 1.5 V _n	0.1	0.01	Crest factor ≤1.5
Current phase sequence components	0 – 5.0 I _n	0.5	0.01	Crest factor ≤3.0
Active Power	0 – 5 P _n	0.5	0.01	For all Power Factors between 0.5 and 1.0
Reactive Power	0 – 5 RP _n	0.5	0.01	For all Power Factors between 0.87 and 1.0
Frequency	42.5 Hz – 57.5 Hz	0.005	0.001	20% < V _n < 150%

The accuracy requirements for fault recording and power quality monitoring shall be in accordance with BS EN 61000-4-30 Class A; the resolution requirements shall support the required accuracy in accordance with IEC 62586-1.



- 6.3.9.4 requires Type C and Type D Power Generation Modules to submit **simulation models**
- ENWL require the model to be in **IPSA format** (G99 allows the particular variety of power system analysis software to be specified)
- Model to be **validated by carrying out simulation studies** in accordance with C.7.8 and documented in a report to be submitted

We need models to simulate:-

- 1) Future network stability as the generation mix changes*
- 2) Model network disturbances such as frequency excursion of 9th August 2019*
- 3) Simulate future DSO network balancing and operation*
- 4) Model future innovative network controls*

Resources






FAQs on
website



EREC G99
webinar
recordings
on
website

Webinar 1
Introduction
to G99
Processes

A graphic of a computer monitor displaying the title slide for Webinar 1. The slide has a dark blue background with white text.

Introduction to EREC G99
Webinar – 12th April 2019

Webinar 2
Technical
Compliance

A graphic of a computer monitor displaying the title slide for Webinar 2. The slide has a dark blue background with white text and a small logo in the top right corner.

EREC G99 Technical Compliance Requirements
Webinar – 30th April 2019

Information available [here](#)

Question & Answer Session





Wrap up and Close

Steffan Jones

Stay connected...



www.enwl.co.uk

Wrap Up & Close



- Please give us your honest feedback on the forms provided
- Presentation slides will be available via our website shortly.
- Don't forget to get in touch with us at ICE@enwl.co.uk
- Thank you for your attendance and have a safe journey home.

