



EREC G98 & G99 update workshop

27th January 2021

Stay connected...



www.enwl.co.uk


Webinar format



40 minutes presentation



20 minutes
questions & answers



Please raise your hand or
submit written questions
online during the webinar

Meet the Team



Ami Mathieson

Incentive on Connections
Engagement Manager



Victoria Brown

Grid & Primary
Programme Manager



Hannah Sharratt

Stakeholder engagement
& regulatory manager



Gill Williamson

Strategic Planning
Manager



Steffan Jones

Infrastructure Solutions
Manager



Brian Hoy

Head of Market
Regulation


Agenda



Reminders, hints and
tips



Power quality
compliance



Type C & D pointers



Storage update



Industry update



Questions &
Answers


Useful reminders, hints and tips



EREC G98 & G99 - G99 Types (GB)



- Types affect technical requirements and which forms you use



EREC G98 & G99 – Introduction and forms



<https://www.enwl.co.uk/get-connected/apply-for-a-new-connection/generation-and-storage/g99/>



Summary of G98 and G99 Forms

	Single premises Up to and including 16 A per phase	Multiple premises Up to and including 16 A per phase	Less than 50kW	Integrated Micro-generation & storage (each up to & including 16 A per phase)	Greater than 50kW & less than 1MW Type A	1MW to less than 10MW Type B	10MW to less than 50MW Type C	Greater than or equal to 50MW or >110kV Type D
Applicable Standard	G98	G98	G99	G99	G99	G99	G99	
Application		Form A	Form A1-1	Form A1-2	SAF*	SAF*	SAF*	
Notification	Form B	Form B	Form A3-1	Form A3-2	Form A3-1			
Evidence	If fully type tested but not registered with the ENA- Form C	If fully type tested but not registered with the ENA- Form C	If not type tested – Form A2-1 synchronous <50kW, Form A2-2 synchronous >50kW or Form A2-3 inverter connected gen	If not type tested – Form A2-1 synchronous <50kW, Form A2-2 synchronous >50kW or Form A2-3 inverter connected gen	If not type tested- Form A2-2 synchronous Form A2-3 inverter connected gen	PGMD** Form B2-1	PGMD** Form C2-1	
Site Compliance and Commissioning Checks					Form A2-4 if the Interface Protection is not Type Tested or for other site compliance tests	Form B2-2 if the Interface Protection is not Type Tested or for other site compliance tests	Form C2-2 if the Interface Protection is not Type Tested or for other site compliance tests	
Installation						Form B3	Form C3	

*Standard Application Form

**Power Generating Module Document

EREC G98 & G99 - ENA type test register



ENA Type Test Register is available @ <https://www.ena-eng.org/gen-ttr/>

ENA now review manufacturers' data

- Approx. 1500 devices
- Colour coded
 - **Compliant**
 - **Awaiting assessment**
 - Further information required

The screenshot shows the ENA Type Test Register interface. On the left, there are search filters for Manufacturer (Solis (Ginlong)), Device Category (Inverter), Device Type (PV), Compliance Status (Awaiting assessment), and Published between (Month/Year). The main area displays '34 Devices Found' with a table of results. The table has columns for System Reference, Compliance Status, Published date, Manufacturer, Model, Category, Type, Registered Capacity, and No. of Phases. The devices are color-coded: orange for 'Awaiting assessment' and green for 'Compliant'.


System Reference	Compliance Status	Published	Manufacturer	Model	Category	Type	Registered Capacity	No. of Phases
SOLIS/02936/V1	Awaiting assessment	20 Jan 2021	Solis (Ginlong) (previously Ningbo Ginlong)	RHI-3P10K-HVES-5G	Inverter	PV	10 kW	Three
SOLIS/02935/V1	Awaiting assessment	20 Jan 2021	Solis (Ginlong) (previously Ningbo Ginlong)	RHI-3P8K-HVES-5G	Inverter	PV	8 kW	Three
SOLIS/02500/V1	Compliant	7 Oct 2020	Solis (Ginlong) (previously Ningbo Ginlong)	RHI-3P10K-HVES-5G	Inverter	PV	10 kW	Three
SOLIS/02499/V1	Compliant	7 Oct 2020	Solis (Ginlong) (previously Ningbo Ginlong)	RHI-3P8K-HVES-5G	Inverter	PV	8 kW	Three
SOLIS/00797/V1/A3	Compliant	11 Mar 2020	Solis (Ginlong) (previously Ningbo Ginlong)	Solis-3P9K-4G	Inverter	PV	9 kW	Three

- Good engagement with manufacturers, including large players such as Tesla
- Automated monthly reminders sent to manufacturers chasing outstanding information

EREC G98 & G99 – Generator connection process



Generator



Customer

**Initial
synchronisation**
allowed after
satisfactory review of
initial submission

Temporary
(up to 6 months)
access to distribution
network whilst
finalising compliance

**Permanent
access to
distribution
network**

**PGMD
Iterations**


**Final
PGMD**

FON

ENWL compliance checks

Connection agreement


Connection agreement
inc. FON



EREC G98 & G99 – Generator connection process



Generator



Customer

**Initial
synchronisation**
allowed after
satisfactory review of
initial submission

Temporary
(up to 6 months)
access to distribution
network whilst
finalising compliance

**Permanent
access to
distribution
network**

**PGMD
Iterations**

**Final
PGMD**

FON


ENWL compliance checks

**We recommend
Generators start early
to avoid delays to
synchronisation**

Connection agreement

Connection agreement
inc. FON


EREC G98 & G99 - IDNO connections




- The generator must still comply with EREC G99 when connecting to an IDNO network
- IDNO undertakes detailed checks on the compliance of generators connecting to an IDNO network
- ENWL don't do detailed checks but seek/receive conformation of complete compliance



EREC G99 requires that generators comply with reactive power capabilities of 0.95 lead/0.95 lag at the point of connection, but there is some flexibility.



- **Dedicated network**
- A load flow study showing ± 0.95 power factor at the point of connection is required
- A capability curve is not proof of compliance



- **Embedded in large network**
- It is possible to show compliance of 0.95 lead/0.95 lag at the generator terminals
- It is not necessary for the generator to compensate for reactive losses in a large transformer between the generator and the point of connection.

EREC G98 & G99 - Site specific versus generic (Type B)



Site specific simulations

- Flicker
- Harmonics
- Reactive power (inc gen tx)
- Limited Frequency Sensitive – over frequency
- Fault ride through

**Down to Generator
Manufacturers help with data**

Generic tests acceptable

- Frequency ranges
- Frequency response tests (step and ramp)
- Output with falling frequency

**Manufacturers
information**

Site specific tests

- B2-2 form tests
- B3 form tests
- Reconnection

**Down to
Generator**



Get ahead by testing your G99 relay early...

We recommend that you don't leave G99 relay testing to the last minute;

- G99 relays can be bench tested and do not need to be tested in-situ
- They can be tested by the Generator's commissioning engineer at any point throughout the construction stage
- Testing and witnessing can be arranged with our commissioning engineer well ahead of energisation



Power Quality Compliance





Engineering Recommendation G5

Issue 5 2020

Harmonic voltage distortion and the connection of harmonic sources and/or resonant plant to transmission systems and distribution networks in the United Kingdom

Implementation – 17th June 2020

There are major changes affecting Electricity North West and our customers

G99 compliance checks require a site specific harmonic assessment to demonstrate compliance with G5/5

Only G98 < 16A/phase type testing means that there is no need for further assessment when connecting at LV

Type testing is not sufficient evidence of compliance in any other circumstance



	LV POC	HV POC	POC at 33kV and above
Assessment method	ENWL do checks Generator provides information Generator may need to do further assessments	Generator does assessment	Generator does stage 3 assessment
Background harmonic measurements	5 th , 21 st and 37 th harmonic background voltages may be required We shall tell you and arrange measurements	Harmonic background voltages may be required Tell us and we arrange measurements	ENWL provide Harmonic Specification
Information from ENWL		Fault level	Harmonic Specification
Synchronous generators	Use ENWL guidance note	Use ENWL guidance note	Full assessment required



We have created a guidance note explaining a simplified approach for checking G5/5 compliance of LV and HV synchronous generators

Customer Guidance Note - Electricity North West's approach for assessing G5/5 harmonic compliance of LV & HV synchronous generators as required by G99



Generator connections must comply with EREC G5/5 "Harmonic voltage distortion and the connection of harmonic sources and/or resonant plant to transmission systems and distribution networks in the United Kingdom". Since the first substages of G5/5 Stages 1 and 2 only relate to the assessment of inverter equipment, it is recommended that synchronous generators are initially assessed based on their harmonic currents versus the limits tabulated below. Compliance with the tabulated limits should be evidenced by providing to Electricity North West the synchronous generator's harmonic current technical data and a comparison showing the harmonic currents to be less than or equal to the given limits.

Based on G5/5's harmonic voltage planning limits, the tabulated LV and HV current limits are determined assuming fault levels of 10MVA and 100MVA respectively that should be used to start with. If you find that given limits are exceeded, then please request Electricity North West to provide the fault level for your specific point of connection. Limits for other fault levels can be derived by scaling the given harmonic current limits up or down accordingly; for example, LV harmonic current limits corresponding to a fault level of 5MVA are derived by halving the tabulated LV current limits and doubling them for a fault level of 20MVA. HV limits corresponding to a fault level of 50MVA are calculated by halving the tabulated HV current limits, whilst limits corresponding to a fault level of 200MVA are double the tabulated HV current limits.

Use of the tabulated current limits for assessing the compliance of HV synchronous generators assumes that background harmonic distortion levels are less than 75% of planning limits and there is no need to measure background levels initially. HV background harmonics only need to be measured if the tabulated harmonic current limits referred to the specific fault level are exceeded.

	LV Synchronous Generator Harmonic Current Limit (Amps)	HV Synchronous Generator Harmonic Current Limit (Amps)		LV Synchronous Generator Harmonic Current Limit (Amps)	HV Synchronous Generator Harmonic Current Limit (Amps)
h			h		
2	28.87	4.92	26	1.47	0.27
3	48.11	6.56	27	1.41	0.26
4	9.02	1.64	28	1.36	0.25
5	52.48	7.16	29	5.68	1.03
6	5.47	0.99	30	1.27	0.23
7	37.48	5.11	31	4.97	0.90
8	6.56	0.60	32	1.19	0.22
9	17.49	3.18	33	1.16	0.21
10	5.25	0.95	34	1.12	0.20
11	52.07	6.31	35	3.90	0.71
12	3.18	0.58	36	1.06	0.19
13	36.72	5.34	37	3.49	0.63
14	2.73	0.50	38	1.00	0.18
15	6.36	0.93	39	0.98	0.18
16	2.39	0.43	40	0.95	0.17
17	17.97	3.27	41	2.84	0.52
18	2.12	0.39	42	0.91	0.17
19	12.06	2.74	43	2.58	0.47
20	1.91	0.35	44	0.87	0.16
21	1.82	0.33	45	0.85	0.15
22	1.74	0.32	46	0.83	0.15
23	9.96	1.81	47	2.16	0.39
24	1.59	0.29	48	0.80	0.14
25	7.64	1.39	49	1.99	0.36
			50	0.76	0.14

June 2020



G5/5 Stage 3 assessment is required for generator connections at 33kV and above, plus connections that fail Stage 2

**Harmonic
Specification**

=

Impedance profile of the PCC

Background harmonic level

Incremental Harmonic Voltage Limit

Total Harmonic Voltage Limit

ENWL

**Harmonic
Specification**

Customer

**Harmonic
Assessment**

For review

ENWL

PGMD ✓

Type C and D pointers






Type C & D
generators
require fault
and dynamic
monitoring
(C6)



ENWL are
working with
other DNOs
and
manufacturers
to develop
threshold
settings



C6 is being
modified to
address
detailed
parameters
after informal
consultation



National Grid
are changing
the Grid Code
in line with the
proposed
changes to C6



**A simulation model is required
(G99 6.3.9.3.)**

Governor frequency control
model &
Exciter voltage control model

Compatible with IPSA2

**Model validation is required
(C.7.8)**

Necessary simulation studies
are defined

Simulation results to be
overlaid on top of test results

Storage update





G98/99 has limited application for storage, but the exclusions will be removed after approval

Changes to European law is requiring much more comprehensive application to storage after September 2022

Changes are coming to G99 and forms

A Distribution Code public consultation is seeking the views on proposed changes drafted to cover the increased requirement (Deadline: 17:00 Friday 12th February 2021)

[DCRP/20/06/PC Consultation Pack](#)



Distribution Code Consultation DCRP/20/06/PC

Storage Modification to G98 G99 and DCode(v45)

Removal of Exclusions to Storage from DCode Documentation



Terms & definitions changed

New Power Generating Facility / Power Park Module diagrams including storage are being added

Electric Vehicles operating in vehicle to grid mode (V2G) are included (G99 only)

Not applicable to non-controllable storage such as synchronous compensators and synchronous flywheels

Storage required to switch from import to export when system frequency falls below 49.5Hz

Industry update






In October 2020, Connection guides were updated to ensure that they were an accurate reflection of G98 and G99 processes and requirements.

The below guides have been revised;

- G98 Multiple Premises
- G98 Multiple Summary Guide
- G98 Single Premises
- G98 Single Summary
- G99 Type A
- G99 Type A Final Summary
- G99 Type B-D Final Summary



Detailed revisions can be found at <http://www.dcode.org.uk/current-areas-of-work/dg-connection-guides.html>

Further updates expected including exemplars of completed forms and evidence



Minor technical/housekeeping modifications to G98 and G99 are in the pipeline

G98 Amendment 5 and G99 Amendment 7 will be issued after consultation and approval

Need to comply with cyber security requirements

Introduction of a minimum fault level for simulations

Formal allowing of a family approach to type testing

Modifications to C6

Clarification of processes for compliance checking of infrequent short term parallel generators

DNO option to request detailed models for Types A&B

Modifications to C6

Changes to forms reflecting feedback on their use such as “E” for exempt

Numerous clarifications

Any questions?





Electricity North West Website

<https://www.enwl.co.uk/get-connected/new-connection/generation-connection/engineering-recommendation-g99>

ENA Website

<http://www.energynetworks.org/electricity/engineering/distributed-generation/engineering-recommendation-g59.html>

DG Connection Guides

<http://www.energynetworks.org/electricity/engineering/distributed-generation/dg-connection-guides.html>

Distribution Code DPC7

covers requirements for embedded generator including G99

<http://www.dcode.org.uk/>




FAQs on
website



Meet with
our experts

Webinar recordings on our website

Webinar 1
Introduction
to G99
Processes



Webinar 2
Technical
Compliance





	Sign up to our distribution list by emailing us at ice@enwl.co.uk
	ICE@enwl.co.uk
	0800 195 4141
	@ElecNW_News
	linkedin.com/company/electricity-north-west
	facebook.com/ElectricityNorthWest
	youtube.com/ElectricityNorthWest

Please contact us if you have any questions
Webinar slides will be circulated to all registered delegates



**Thank you for your participation in
today's session**