



**electricity
north west**

Bringing energy to your door



Celsius

Network Improvements and System Operability

Delroy Ainsworth & Olivia Carpenter-Lomax

LCNI conference

Thursday 31 October 2019

Stay connected...



www.enwl.co.uk



Funded by the
**2015 Network
Innovation
Competition**

Project runs from
**January 2016 to
March 2020**

Total project cost:
£5.5m

Estimated **benefit of
£500m** over Great
Britain up to 2050

Project partners





Lead partner,
distribution
network operator

Technical partner,
focusing on trial
design, analysis,
deliverable
development

Providing
monitoring
equipment for
trials

Customer
engagement
partner

London and South
East distribution
network operator







Celsius aims to increase capacity in distribution substations, enabling connection of low carbon technologies and reducing the need for costly substation reinforcement

Assets have nominal thermal rating
Ratings = °C
Ratings \neq amps

Diverse range of environments
Small changes in environmental factors can result in very different actual ratings

Assumed thermal ratings can lead to capacity being under-utilised or unnecessary risk



Thermal analysis	 q_{core} Internal asset temperature = Thermal coefficient \times External asset temperature  q_{external}
Thermal flow study	 Research into heat and air flows for optimal substation design
Asset health study	 Examines effects of increased load and cooling techniques on assets


Step 1: Fit thermal monitoring




Learning

Deliverable

Benefit



Step 2: Retrofit cooling





Improving ventilation




Supported by the Thermal Flow Study results, which will provide guidance about the best ventilation arrangements

Painting outdoor transformers




White paint will be used to reflect solar heating of the asset

Shading outdoor transformers



To protect from solar radiation

Cable backfill



Backfilling cable ducts with a material with beneficial thermal properties, to allow heat to escape from cables more effectively

Improving ventilation



Painting outdoor transformers



Shading outdoor transformers





External view




Internal view



Negative pressure active cooling – Ekkosense



Celsius methodology outline






Phase 1: Monitoring trial

Factor report, focused on transformer temperature, published in September 2018 (updated in October 2019)

Phase 2: Cooling technology

Cooling technology report produced in September 2019 (to be updated with additional data at the end of 2019)



Negative pressure ventilation
Installed at 20 sites

Positive pressure ventilation
Installed at 20 sites

Improving passive ventilation at substations
Installed at 41 sites

Painting outdoor transformers
Installed at 10 sites

Shading outdoor transformers
Installed at 5 sites

Improved cable backfill
Installed at 4 sites



Phase 1: Monitoring trial

A more informed rating can be derived for a transformer by using two temperature measurements and three phase power.

Most transformers have more capacity than their nominal ratings suggest for most of the time – their more informed daily ratings are on average ~30% higher than nominal.

There are factors that impact the operating temperature of a transformer. These include:

Building environment

Season

External weather temperature

Transformer age

Harmonics

Eg A transformer installed outside in winter has ~20% higher calculated daily rating, on average, than a transformer installed in a brick built substation in the middle of summer.

Even taken together, these factors cannot be used to derive the improved rating; the correlation is not strong enough to build a model without using measured data.

Phase 2: Cooling technology

Retrofit cooling technologies can be used to cool the transformer, and therefore release further capacity

Negative pressure ventilation

12% average improvement (conservative view) in transformer ratings, wide variety of impacts from site to site

Positive pressure ventilation

14% average improvement (conservative view) in transformer ratings, site performance is generally consistent

Improving passive ventilation at substations

A very wide range of impacts, with improvement in some sites, and many others with no significant change.

Painting outdoor transformers

4% average improvement in the daily rating. Not all sites saw improvement.

Shading outdoor transformers


Only limited data available due to loading issues. Data suggest an improvement in the daily rating of about 3.6%.

Improved cable backfill

Not assessed

Preliminary results

Celsius BAU process





**Cost benefit
analysis of
Celsius
approaches**



Celsius tool

**Business as
usual
recommendations**



**Future work
to refine
Celsius findings**

QUESTIONS & ANSWERS

Please contact us if you have any questions or would like to arrange a one-to-one briefing about our innovation projects



innovation@enwl.co.uk



olivia.carpenter-lomax@ricardo.com



www.enwl.co.uk/innovation



0800 195 4141



[@ElecNW_News](https://twitter.com/ElecNW_News)



[linkedin.com/company/electricity-north-west](https://www.linkedin.com/company/electricity-north-west)



[facebook.com/ElectricityNorthWest](https://www.facebook.com/ElectricityNorthWest)



[youtube.com/ElectricityNorthWest](https://www.youtube.com/ElectricityNorthWest)